

# Annual Environmental Report

2019



Kinsale

D0132-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 KINSALE WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - KINSALE WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - KINSALE WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR KINSALE WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO KINSALE WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER

This Annual Environmental Report has been prepared for D0132-01, Kinsale, in Cork in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There was no major capital or operational changes undertaken

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- KINSALE WWTP with a Plant Capacity PE of 9800, the treatment type is 3NP - Tertiary N&P removal

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0500D0132SW001	KINSALE WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l ortho-Phosphate (as P) - unspecified mg/l

## 1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
<b>There are no Licence Specific Reports included in the AER.</b>	

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 KINSALE WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - KINSALE WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
COD-Cr mg/l	4	1489	343.63
Suspended Solids mg/l	4	284	107.69
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	4	183	62.31
Hydraulic Capacity	N/A	11820	3905

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0500D0132SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	12	N/A	N/A	42.95	Pass
<b>Suspended Solids mg/l</b>	35	87.5	N/A	12	1	N/A	15.55	Pass
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	20	40	N/A	12	N/A	N/A	4.66	Pass
<b>Total Oxidised Nitrogen (as N) mg/l</b>	10	12	N/A	12	N/A	N/A	0.9	Pass
<b>pH pH units</b>	9	9	N/A	12	N/A	N/A	7.52	Pass
<b>Ammonia-Total (as N) mg/l</b>	5	6	N/A	12	4	4	5.59	Fail
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	1	1.2	N/A	12	3	3	0.67	Fail
<b>Total Nitrogen mg/l</b>	N/A	N/A	N/A	12	N/A	N/A	10.29	
<b>Enterococci (Intestinal) no./100mls</b>	N/A	N/A	N/A	12	N/A	N/A	330.36	

<b>Faecal coliforms no./100mls</b>	N/A	N/A	N/A	12	N/A	N/A	1473.86	
<b>E. Coli no./100mls</b>	N/A	N/A	N/A	12	N/A	N/A	840.97	
<b>Total Phosphorus (as P) mg/l</b>	N/A	N/A	N/A	12	N/A	N/A	0.89	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

### Cause of Exceedance(s):

**Ammonia and Ortho P did not meet the ELVs set in the WWDL. Influent COD loadings were over design during the month which has an impact on the treatment plant.**

### Significance of Results:

The WWTP is not compliant with the ELVs set in the WWDL. Influent COD loadings were over design during the month which has an impact on the treatment plant.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0500D0132SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.



Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	161854.74, 50048.75	TW05003167BN2006	No	No	No	Yes	Moderate
Downstream	163204.61, 49048.98	TW05003167BN2007	No	No	No	Yes	Moderate

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ammonia concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - KINSALE WWTP

### 2.1.4.1 Treatment Efficiency Report - KINSALE WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	N/A	1066	N/A

<b>cBOD</b>	119352	5565	95
<b>SS</b>	206269	18583	91
<b>TN</b>	N/A	12299	N/A
<b>COD</b>	658165	51344	92

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - KINSALE WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

KINSALE WWTP	
<b>Peak Hydraulic Capacity (m<sup>3</sup>/day) - As Constructed</b>	6615
<b>DWF to the Treatment Plant (m<sup>3</sup>/day)</b>	2205
<b>Current Hydraulic Loading - annual max (m<sup>3</sup>/day)</b>	11820
<b>Average Hydraulic loading to the Treatment Plant (m<sup>3</sup>/day)</b>	3905
<b>Organic Capacity (PE) - As Constructed</b>	9800
<b>Organic Capacity (PE) - Collected Load (peak week)<sup>Note1</sup></b>	8263
<b>Organic Capacity (PE) - Remaining</b>	1537
<b>Will the capacity be exceeded in the next three years? (Yes/No)</b>	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - KINSALE WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Industrial / Commercial Sludge	30	Volume (m3)		100	Yes	Yes	No
Industrial / Commercial Sludge	30	Volume (m3)		100	Yes	Yes	No
Industrial / Commercial Sludge	30	Volume (m3)		100	Yes	Yes	No
Industrial / Commercial Sludge	30	Volume (m3)		100	Yes	Yes	No
Industrial / Commercial Sludge	30	Volume (m3)		100	Yes	Yes	No

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2019.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Abatement Equipment offline	Plant or equipment maintenance at WWTP	1	No	Yes
Uncontrolled release	EO caused by pump failure	1	No	Yes
Breach of ELV	Shock load to the WWTP	1	Yes	No

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Abatement Equipment offline	Plant or equipment maintenance at WWTP	1	No	Yes
Uncontrolled release	EO caused by power failure	1	No	Yes
Breach of ELV	Other	1	No	No
Uncontrolled release	Network Infrastructure	1	Yes	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2019	6
Number of Incidents reported to the EPA via EDEN in 2019	6
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
TBC	163040, 49563	No	Low	Meeting	Unknown	Unknown	Not Monitored
TBC	TBC	No	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	TBC	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SW2	165485, 49081	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
SW3	164236, 50240	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
TBC	164249, 49705	No	Low	Meeting	Unknown	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
TBC	TBC	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>There are no Specified Improvement Programmes for this Agglomeration.</b>							

A summary of the status of any improvements identified by under Condition 5.2 is included below.

#### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

#### 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.



## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2015	No	

### 5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2015

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	Yes
List reason e.g. additional SWO identified	Additional SWOs identified
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 23/04/2020

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

## 7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				Current WFD Status	Mean (mg/l)		
			Bathing Water	Drinking Water	FWPM	Shellfish		cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream Monitoring Point	161854.74, 50048.75	TW05003167BN2006					Moderate	0.700	0.018	0.050
Downstream Monitoring Point	163204.61, 49048.98	TW05003167BN2007	No	No	Yes	No	Moderate	1.177	0.019	0.087
Difference								0.477	0.001	0.037
EQS								4.000	0.040	N/A
% of EQS								11.925%	2.500%	#VALUE!

Upstream Monitorign Location

WaterbodyN: WaterbodyC: MonitoringStationCode	MonitoringSt	SampleDate	SampleMethr	ParameterNa	ParameterUn	Result	TextResult	LimitOfDetec	ReportResult	ReportTextRe	ReportResult:	ReportLimit
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface	Ammonia-To	mg/l	0.043		0.01	0.043		OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom	Ammonia-To	mg/l	0.043		0.01	0.043		OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom	Ammonia-To	mg/l	0.066		0.01	0.066		OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface	Ammonia-To	mg/l	0.065		0.01	0.065		OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom	Ammonia-To	mg/l	0.047		0.01	0.047		OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface	Ammonia-To	mg/l	0.04		0.01	0.04		OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface	BOD - 5 days	mg/l	<1	<1	1	0.5	<1	OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom	BOD - 5 days	mg/l	<1	<1	1	0.5	<1	OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface	BOD - 5 days	mg/l	<1	<1	1	0.5	<1	OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom	BOD - 5 days	mg/l	1.3		1	1.3		OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface	Chlorophyll	µg/l	<1	<1	1	0.5	<1	OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom	Chlorophyll	µg/l	<1	<1	1	0.5	<1	OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom	Chlorophyll	µg/l	3.5		1	3.5		OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface	Chlorophyll	µg/l	6.9		1	6.9		OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom	Chlorophyll	µg/l	5.9		1	5.9		OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface	Chlorophyll	µg/l	5.2		1	5.2		OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface	Depth	m	0			0		OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom	Depth	m	6.8			6.8		OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom	Depth	m	4.7			4.7		OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface	Depth	m	0			0		OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom	Depth	m	4.8			4.8		OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface	Depth	m	0			0		OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface	Dissolved Oxy	% Saturation	98		1	98		OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom	Dissolved Oxy	% Saturation	92		1	92		OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface	Dissolved Oxy	% Saturation	91		1	91		OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom	Dissolved Oxy	% Saturation	90		1	90		OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface	Dissolved Oxy	% Saturation	106		1	106		OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom	Dissolved Oxy	% Saturation	104		1	104		OK	1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom	ortho-Phosph	mg/l	0.024		0.005	0.024		OK	0.005
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface	ortho-Phosph	mg/l	0.025		0.005	0.025		OK	0.005
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface	ortho-Phosph	mg/l	0.024		0.005	0.024		OK	0.005
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom	ortho-Phosph	mg/l	0.02		0.005	0.02		OK	0.005
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom	ortho-Phosph	mg/l	0.0088		0.005	0.0088		OK	0.005
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface	ortho-Phosph	mg/l	0.012		0.005	0.012		OK	0.005
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom	pH	pH units	7.9		2	7.9		OK	2
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface	pH	pH units	7.8		2	7.8		OK	2
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface	pH	pH units	7.9		2	7.9		OK	2
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom	pH	pH units	8		2	8		OK	2
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface	pH	pH units	8.2		2	8.2		OK	2
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom	pH	pH units	8.1		2	8.1		OK	2
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface	Salinity	PSU	15.3		0.1	15.3		OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom	Salinity	PSU	33.1		0.1	33.1		OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface	Salinity	PSU	25.2		0.1	25.2		OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom	Salinity	PSU	26.5		0.1	26.5		OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface	Salinity	PSU	30.3		0.1	30.3		OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom	Salinity	PSU	31.7		0.1	31.7		OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface	Salinity(Lab)	0/oo	13.8		0.1	13.8		OK	0.1

Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom Salinity(Lab) 0/oo	32.1	0.1	32.1	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface Salinity(Lab) 0/oo	24.8	0.1	24.8	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom Salinity(Lab) 0/oo	26.1	0.1	26.1	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface Salinity(Lab) 0/oo	30.6	0.1	30.6	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom Salinity(Lab) 0/oo	31.8	0.1	31.8	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom Silica (as SiO <sub>2</sub> mg/l	0.5	0.1	0.5	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface Silica (as SiO <sub>2</sub> mg/l	2.3	0.1	2.3	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom Silica (as SiO <sub>2</sub> mg/l	0.89	0.1	0.89	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface Silica (as SiO <sub>2</sub> mg/l	0.99	0.1	0.99	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom Silica (as SiO <sub>2</sub> mg/l	<0.1	0.1	0.05 <0.1	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface Silica (as SiO <sub>2</sub> mg/l	<0.1	0.1	0.05 <0.1	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface StationDepth m	7.5	0.1	7.5	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom StationDepth m	7.5	0.1	7.5	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface StationDepth m	5	0.1	5	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom StationDepth m	5	0.1	5	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom StationDepth m	5	0.1	5	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface StationDepth m	5	0.1	5	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom Temperature °C	10		10	OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface Temperature °C	10.5		10.5	OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface Temperature °C	15.3		15.3	OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom Temperature °C	14.8		14.8	OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom Temperature °C	15.8		15.8	OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface Temperature °C	16		16	OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface Total Oxidise mg/l	2.6	0.01	2.6	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom Total Oxidise mg/l	0.38	0.01	0.38	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom Total Oxidise mg/l	0.39	0.01	0.39	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface Total Oxidise mg/l	0.44	0.01	0.44	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface Total Oxidise mg/l	0.12	0.01	0.12	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom Total Oxidise mg/l	0.08	0.01	0.08	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Surface Transparency m	2		2	OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	28/02/2019 12:11	TRaC Bottom Transparency m	2		2	OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Bottom Transparency m	0.7		0.7	OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/08/2019 11:15	TRaC Surface Transparency m	0.7		0.7	OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Bottom Transparency m	2.9		2.9	OK	
Lower Bando IE_SW_080_C TW05003167BN2006	BN080 - Whit	19/09/2019 11:31	TRaC Surface Transparency m	2.9		2.9	OK	

#### Downstream Monitoring Location

WaterbodyN: WaterbodyCc MonitoringStationCode	MonitoringSt	SampleDate	SampleMethr	ParameterNa	ParameterUn	Result	TextResult	LimitOfDetec	ReportResult	ReportTextRe	ReportResult	ReportLimit
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29	TRaC Surface	Ammonia-To	mg/l	0.034		0.01	0.034		OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29	TRaC Bottom	Ammonia-To	mg/l	0.033		0.01	0.033		OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	06/03/2019 12:15	Grab	Ammonia-To	mg/l	0.05		0	0.05			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	15/05/2019 09:25	Grab	Ammonia-To	mg/l	0.51		0	0.51			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	03/07/2019 13:00	Grab	Ammonia-To	mg/l	0.059		0	0.059			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08	TRaC Surface	Ammonia-To	mg/l	0.047		0.01	0.047		OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08	TRaC Bottom	Ammonia-To	mg/l	0.048		0.01	0.048		OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36	TRaC Bottom	Ammonia-To	mg/l	0.065		0.01	0.065		OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36	TRaC Surface	Ammonia-To	mg/l	0.062		0.01	0.062		OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10	TRaC Depth C	Ammonia-To	mg/l	0.081		0.01	0.081		OK	0.01

Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface	Ammonia-To	mg/l	0.043	0.01	0.043	OK	0.01	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Bottom	Ammonia-To	mg/l	0.089	0.01	0.089	OK	0.01	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	20/11/2019 10:20 Grab	Ammonia-To	mg/l		0	0.0175	<0.035	0.035	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Surface	BOD - 5 days	mg/l	<1	1	0.5	<1	OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Bottom	BOD - 5 days	mg/l	<1	1	0.5	<1	OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	06/03/2019 12:15 Grab	BOD - 5 days	mg/l	1.8	1	1.8			1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	15/05/2019 09:25 Grab	BOD - 5 days	mg/l	2.5	1	2.5			1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	03/07/2019 13:00 Grab	BOD - 5 days	mg/l	2	1	2			1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Surface	BOD - 5 days	mg/l	<1	1	0.5	<1	OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface	BOD - 5 days	mg/l	<1	1	0.5	<1	OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Bottom	BOD - 5 days	mg/l	1.2	1	1.2		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	09/10/2019 11:00 Grab	BOD - 5 days	mg/l	1.1	1	1.1			1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Surface	Chlorophyll	µg/l	<1	1	0.5	<1	OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Bottom	Chlorophyll	µg/l	<1	1	0.5	<1	OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Surface	Chlorophyll	µg/l	3.1	1	3.1		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Bottom	Chlorophyll	µg/l	2.2	1	2.2		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Depth C	Chlorophyll	µg/l	3.4	1	3.4		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Bottom	Chlorophyll	µg/l	3.4	1	3.4		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface	Chlorophyll	µg/l	4.3	1	4.3		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Bottom	Depth	m	8.8		8.8		OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Surface	Depth	m	0		0		OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Surface	Depth	m	0		0		OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Bottom	Depth	m	8.5		8.5		OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Surface	Depth	m	0		0		OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Bottom	Depth	m	5.5		5.5		OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Depth C	Depth	m	0		0		OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Bottom	Depth	m	4.8		4.8		OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface	Depth	m	0		0		OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Bottom	Depth	m	6.8		6.8		OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Surface	Dissolved O <sub>2</sub>	% Saturation	99	1	99		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Bottom	Dissolved O <sub>2</sub>	% Saturation	97	1	97		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	06/03/2019 12:15 Grab	Dissolved O <sub>2</sub>	% Saturation	100.1	0	100.1			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	15/05/2019 09:25 Grab	Dissolved O <sub>2</sub>	% Saturation	107.1	0	107.1			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	03/07/2019 13:00 Grab	Dissolved O <sub>2</sub>	% Saturation	101.5	0	101.5			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Surface	Dissolved O <sub>2</sub>	% Saturation	125	1	125		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Bottom	Dissolved O <sub>2</sub>	% Saturation	113	1	113		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Surface	Dissolved O <sub>2</sub>	% Saturation	90	1	90		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Bottom	Dissolved O <sub>2</sub>	% Saturation	87	1	87		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Depth C	Dissolved O <sub>2</sub>	% Saturation	88	1	88		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Bottom	Dissolved O <sub>2</sub>	% Saturation	90	1	90		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface	Dissolved O <sub>2</sub>	% Saturation	104	1	104		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Bottom	Dissolved O <sub>2</sub>	% Saturation	102	1	102		OK	1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	09/10/2019 11:00 Grab	Dissolved O <sub>2</sub>	% Saturation	97.6	0	97.6			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	20/11/2019 10:20 Grab	Dissolved O <sub>2</sub>	% Saturation	98.2	0	98.2			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	06/03/2019 12:15 Grab	E. Coli	no./100mls	2282	0	2282			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	15/05/2019 09:25 Grab	E. Coli	no./100mls		0	5	<10		10
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	03/07/2019 13:00 Grab	E. Coli	no./100mls	10	0	10			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	09/10/2019 11:00 Grab	E. Coli	no./100mls	583	0	583			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	06/03/2019 12:15 Grab	Enterococci (l	no./100mls	833	0	833			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	15/05/2019 09:25 Grab	Enterococci (l	no./100mls		0	5	<10		10



Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	03/07/2019 13:00	Grab	Enterococci (Ino./100mls)		0	5 <10		10	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	09/10/2019 11:00	Grab	Enterococci (Ino./100mls)	109	0	109			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	06/03/2019 12:15	Grab	Faecal colifor no./100mls	3255	0	3255			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	15/05/2019 09:25	Grab	Faecal colifor no./100mls		0	5 <10		10	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	03/07/2019 13:00	Grab	Faecal colifor no./100mls	41	0	41			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	09/10/2019 11:00	Grab	Faecal colifor no./100mls	538	0	538			
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29	TRaC Surface	ortho-Phosph mg/l	0.018	0.005	0.018	OK	0.005	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29	TRaC Bottom	ortho-Phosph mg/l	0.023	0.005	0.023	OK	0.005	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08	TRaC Bottom	ortho-Phosph mg/l	0.007	0.005	0.007	OK	0.005	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08	TRaC Surface	ortho-Phosph mg/l	0.006	0.005	0.006	OK	0.005	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36	TRaC Surface	ortho-Phosph mg/l	0.016	0.005	0.016	OK	0.005	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36	TRaC Bottom	ortho-Phosph mg/l	0.012	0.005	0.012	OK	0.005	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10	TRaC Depth C	ortho-Phosph mg/l	0.023	0.005	0.023	OK	0.005	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46	TRaC Bottom	ortho-Phosph mg/l	0.064	0.005	0.064	OK	0.005	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46	TRaC Surface	ortho-Phosph mg/l	0.0091	0.005	0.0091	OK	0.005	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29	TRaC Surface	pH	pH units	7.9	2	7.9	OK	2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29	TRaC Bottom	pH	pH units	7.9	2	7.9	OK	2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	06/03/2019 12:15	Grab	pH	pH units	7.9	2	7.9		2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	15/05/2019 09:25	Grab	pH	pH units	8.3	2	8.3		2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	03/07/2019 13:00	Grab	pH	pH units	8.1	2	8.1		2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08	TRaC Surface	pH	pH units	8.3	2	8.3	OK	2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08	TRaC Bottom	pH	pH units	8.3	2	8.3	OK	2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36	TRaC Surface	pH	pH units	8	2	8	OK	2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36	TRaC Bottom	pH	pH units	8	2	8	OK	2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10	TRaC Depth C	pH	pH units	8	2	8	OK	2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46	TRaC Surface	pH	pH units	8.2	2	8.2	OK	2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46	TRaC Bottom	pH	pH units	8.1	2	8.1	OK	2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	09/10/2019 11:00	Grab	pH	pH units	7.9	2	7.9		2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29	TRaC Bottom	Salinity	PSU	33.4	0.1	33.4	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29	TRaC Surface	Salinity	PSU	14.3	0.1	14.3	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08	TRaC Bottom	Salinity	PSU	32.8	0.1	32.8	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08	TRaC Surface	Salinity	PSU	31.5	0.1	31.5	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36	TRaC Surface	Salinity	PSU	28	0.1	28	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36	TRaC Bottom	Salinity	PSU	30.6	0.1	30.6	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10	TRaC Bottom	Salinity	PSU	28	0.1	28	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10	TRaC Depth C	Salinity	PSU	21	0.1	21	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46	TRaC Surface	Salinity	PSU	31.5	0.1	31.5	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46	TRaC Bottom	Salinity	PSU	33	0.1	33	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29	TRaC Bottom	Salinity(Lab)	0/oo	33.3	0.1	33.3	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29	TRaC Surface	Salinity(Lab)	0/oo	14.3	0.1	14.3	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08	TRaC Bottom	Salinity(Lab)	0/oo	32.6	0.1	32.6	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08	TRaC Surface	Salinity(Lab)	0/oo	31.7	0.1	31.7	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36	TRaC Bottom	Salinity(Lab)	0/oo	30	0.1	30	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36	TRaC Surface	Salinity(Lab)	0/oo	27.8	0.1	27.8	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10	TRaC Depth C	Salinity(Lab)	0/oo	24.2	0.1	24.2	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46	TRaC Surface	Salinity(Lab)	0/oo	31.7	0.1	31.7	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46	TRaC Bottom	Salinity(Lab)	0/oo	32.8	0.1	32.8	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29	TRaC Surface	Silica (as SiO <sub>2</sub> mg/l)	2.2	0.1	2.2	OK	0.1	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29	TRaC Bottom	Silica (as SiO <sub>2</sub> mg/l)	0.43	0.1	0.43	OK	0.1	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08	TRaC Surface	Silica (as SiO <sub>2</sub> mg/l)	<0.1	0.1	0.05 <0.1	OK	0.1	

Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Bottom Silica (as SiO <sub>2</sub> mg/l	<0.1	0.1	0.05 <0.1	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Surface Silica (as SiO <sub>2</sub> mg/l	0.73	0.1	0.73	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Bottom Silica (as SiO <sub>2</sub> mg/l	0.54	0.1	0.54	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Depth C Silica (as SiO <sub>2</sub> mg/l	1.1	0.1	1.1	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface Silica (as SiO <sub>2</sub> mg/l	<0.1	0.1	0.05 <0.1	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Bottom Silica (as SiO <sub>2</sub> mg/l	<0.1	0.1	0.05 <0.1	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Surface StationDepth m	9	0.1	9	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Bottom StationDepth m	9	0.1	9	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Surface StationDepth m	9	0.1	9	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Bottom StationDepth m	9	0.1	9	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Surface StationDepth m	6	0.1	6	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Bottom StationDepth m	6	0.1	6	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Depth C StationDepth m	5	0.1	5	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Bottom StationDepth m	5	0.1	5	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Bottom StationDepth m	7	0.1	7	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface StationDepth m	7	0.1	7	OK	0.1
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Surface Suspended Sc mg/l	<13	4	6.5 <13	OK	13
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	06/03/2019 12:15 Grab Suspended Sc mg/l	40	2.5	40		2.5
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	15/05/2019 09:25 Grab Suspended Sc mg/l	15	2.5	15		2.5
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	03/07/2019 13:00 Grab Suspended Sc mg/l	25	2.5	25		2.5
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Surface Suspended Sc mg/l	9	4	9	OK	4
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface Suspended Sc mg/l	4	4	4	OK	4
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	09/10/2019 11:00 Grab Suspended Sc mg/l	26	2.5	26		2.5
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Surface Temperature °C	10.7		10.7	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Bottom Temperature °C	10		10	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	06/03/2019 12:15 Grab Temperature °C	8.7	0	8.7		
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	15/05/2019 09:25 Grab Temperature °C	13.5	0	13.5		
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	03/07/2019 13:00 Grab Temperature °C	17	0	17		
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Bottom Temperature °C	16.5		16.5	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Surface Temperature °C	17.4		17.4	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Surface Temperature °C	15		15	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Bottom Temperature °C	14.1		14.1	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Depth C Temperature °C	16.3		16.3	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Bottom Temperature °C	14.7		14.7	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface Temperature °C	15.8		15.8	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Bottom Temperature °C	15.7		15.7	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	09/10/2019 11:00 Grab Temperature °C	12.8	0	12.8		
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	20/11/2019 10:20 Grab Temperature °C	9.5	0	9.5		
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Bottom TOC (as NPOC mg/l	<2	2	1 <2	OK	2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface TOC (as NPOC mg/l	<2	2	1 <2	OK	2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	06/03/2019 12:15 Grab Total Nitroge mg/l	4.5	0	4.5		
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	15/05/2019 09:25 Grab Total Nitroge mg/l	1	0	1		
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	03/07/2019 13:00 Grab Total Nitroge mg/l	0.72	0	0.72		
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	20/11/2019 10:20 Grab Total Nitroge mg/l	1.57	0	1.57		
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Surface Total Oxidise mg/l	1.6	0.01	1.6	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Bottom Total Oxidise mg/l	0.31	0.01	0.31	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	06/03/2019 12:15 Grab Total Oxidise mg/l	2.3	0	2.3		
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	15/05/2019 09:25 Grab Total Oxidise mg/l		0	0.1 <0.20		0.2
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	03/07/2019 13:00 Grab Total Oxidise mg/l	0.07	0	0.07		
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Bottom Total Oxidise mg/l	0.019	0.01	0.019	OK	0.01

Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Surface Total Oxidiser	mg/l	0.01	0.01	0.01	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Bottom Total Oxidiser	mg/l	0.21	0.01	0.21	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Surface Total Oxidiser	mg/l	0.31	0.01	0.31	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Depth C Total Oxidiser	mg/l	0.48	0.01	0.48	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface Total Oxidiser	mg/l	0.082	0.01	0.082	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Bottom Total Oxidiser	mg/l	0.054	0.01	0.054	OK	0.01
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	20/11/2019 10:20 Grab Total Oxidiser	mg/l	1.34	0	1.34		
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Bottom Transparency	m	2.1		2.1	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Surface Transparency	m	2.1		2.1	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Bottom Transparency	m	2.3		2.3	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	08/07/2019 13:08 TRaC Surface Transparency	m	2.3		2.3	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Bottom Transparency	m	0.9		0.9	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Surface Transparency	m	0.9		0.9	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Bottom Transparency	m	0.9		0.9	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 14:10 TRaC Depth C Transparency	m	0.9		0.9	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface Transparency	m	3.1		3.1	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Bottom Transparency	m	3.1		3.1	OK	
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	28/02/2019 12:29 TRaC Surface True Colour	mg/litre Pt Cc	22	5	22	OK	5
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/08/2019 11:36 TRaC Surface True Colour	mg/litre Pt Cc	7	5	7	OK	5
Lower Bando IE_SW_080_C TW05003167BN2007	BN090 - Kins	19/09/2019 11:46 TRaC Surface True Colour	mg/litre Pt Cc	6	5	6	OK	5