

Annual Environmental Report

2020



Castlebar

D0047-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 CASTLEBAR WWTP - 2020 - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - CASTLEBAR WWTP - 2020
 - 2.1.2 EFFLUENT MONITORING SUMMARY - CASTLEBAR WWTP - 2020 -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CASTLEBAR WWTP - 2020
 - 2.1.5 SLUDGE/OTHER INPUTS TO CASTLEBAR WWTP - 2020

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

Rev 1 Note - Section 4.1.1 Question 1 answer changed to "Unknown". Approved 09/07/2021.

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0047-01, Castlebar, in Mayo in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

None

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- CASTLEBAR WWTP - 2020 with a Plant Capacity PE of 28000, the treatment type is 3NP - Tertiary N&P removal

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2200D0047SW001	CASTLEBAR WWTP - 2020	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 CASTLEBAR WWTP - 2020 - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - CASTLEBAR WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	12	5.4	2.22
COD-Cr mg/l	12	445	161.3
Total Nitrogen mg/l	12	26.5	13.87
Suspended Solids mg/l	12	165	80.63
BOD, 5 days with Inhibition (Carbonaceo mg/l	12	158	63.66
Hydraulic Capacity	N/A	23247	12391

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2200D0047SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	26	N/A	N/A	17.83	Pass
Suspended Solids mg/l	35	87.5	N/A	26	N/A	N/A	3.73	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	25	50	N/A	26	N/A	N/A	1.48	Pass
pH pH units	9	9	N/A	26	N/A	N/A	7.91	Pass
Total Phosphorus (as P) mg/l	2	2.4	N/A	13	N/A	N/A	0.19	Pass
ortho-Phosphate (as P) - unspecified mg/l	0.7	0.84	N/A	13	N/A	N/A	0.08	Pass
Faecal coliforms cfu/100ml	N/A	N/A	N/A	3	N/A	N/A	17911.51	
Enterococci (Intestinal) cfu/100ml	N/A	N/A	N/A	3	N/A	N/A	1766.28	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
E. Coli MPN/100ml	N/A	N/A	N/A	3	N/A	N/A	15781.82	
Ammonia-Total (as N) mg/l	N/A	N/A	N/A	13	N/A	N/A	0.15	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2200D0047SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	121937, 293360	RS34M010500	No	No	No	No	Good
Downstream	123360, 294478	RS34C010400	No	No	No	No	Moderate

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS34M010500	0.944	RS34C010400	1.344	1.5	26.6
Ammonia-Total (as N) mg/l	RS34M010500	0.015	RS34C010400	0.012	0.065	-5
ortho-Phosphate (as P) - unspecified mg/l	RS34M010500	0.013	RS34C010400	0.013	0.035	1.8
Total Oxidised Nitrogen (as N) mg/l	RS34M010500	2.096	RS34C010400	0.53		
Conductivity @25°C µS/cm	RS34M010500	541.8	RS34C010400	491.2		
Chloride mg/l	RS34M010500	22.6	RS34C010400	29.38		
pH pH units	RS34M010500	7.84	RS34C010400	7.977		
Dissolved Oxygen mg/l	RS34M010500	9.4	RS34C010400	10.551		
Temperature °C	RS34M010500	12.56	RS34C010400	12.6		

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Nitrite (as N) µg/l	RS34M010500	2.828	RS34C010400	3.309		
Nitrate (as N) mg/l	RS34M010500	2.096	RS34C010400	0.53		
Alkalinity-total (as CaCO ₃) mg/l	RS34M010500	241.4	RS34C010400	192.4		
Dissolved Oxygen % Saturation	RS34M010500	88.2	RS34C010400	106.4		
Total Hardness (as CaCO ₃) mg/l	RS34M010500	277.6	RS34C010400	227.2		
True Colour mg/litre Pt Co	RS34M010500	50.2	RS34C010400	55.8		

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD, Orthophosphate , concentrations downstream of the effluent discharge is noted.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CASTLEBAR WWTP - 2020

2.1.4.1 Treatment Efficiency Report - CASTLEBAR WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
cBOD	256573	7178	97
COD	650139	86221	87
SS	324995	18038	94
TN	55900	N/A	N/A
TP	8932	801	91

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - CASTLEBAR WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

CASTLEBAR WWTP - 2020	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	23814
DWF to the Treatment Plant (m ³ /day)	7938
Current Hydraulic Loading - annual max (m ³ /day)	23247
Average Hydraulic loading to the Treatment Plant (m ³ /day)	12391
Organic Capacity (PE) - As Constructed	28000
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	18010
Organic Capacity (PE) - Remaining	9990

CASTLEBAR WWTP - 2020

Will the capacity be exceeded in the next three years? (Yes/No)

Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - CASTLEBAR WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Other	4565	Volume (m3)	63	0.22	Yes	No	No

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
1	Blocked Sewer	0	1

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	Network Infrastructure	1	Yes	No
Uncontrolled release	Adverse Weather	1	No	Yes
Other	Shock load to the WWTP	1	No	Yes

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	Adverse Weather	1	No	Yes

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	4
Number of Incidents reported to the EPA via EDEN in 2020	4
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SWO-1	115567, 291141	Yes	Medium	Meeting	67	405697	Monitored
SWO10 (SEC 9)	115047, 289624	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO11 (SEC 10)	115218, 289097	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO12 (SEC 11)	115815, 288693	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO13 (SEC 12)	116074, 287994	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO14 (SEC 13)	116138, 287196	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SWO15 (SEC 14)	116364, 289713	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO16 (SEC 15)	117127, 289849	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO17 (SEC 16)	115707, 291355	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO18 (SEC 17)	116964, 292029	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO19 (SEC 18)	115100, 292151	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO2 (SEC 1)	115258, 291679	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
SWO20 (SEC 19)	115637, 291246	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO3 (SEC 2)	113970, 291267	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO4 (SEC 3)	113789, 290755	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO5 (SEC 4)	113298, 290755	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SWO6 (SEC 5)	113298, 291363	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO7 (SEC 6)	113210, 290776	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO8 (SEC 7)	112850, 290582	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SWO9 (SEC 8)	112189, 290205	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	Yes

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0047-SIP:01	Increase holding capacity of SW2-SWO to treat flows in excess of 3DWF	C	01/12/2010	Yes	Works Completed		
D0047-SIP:02	Upgrade of the WWTP (DBO contract)	C	01/12/2010	Yes	Works Completed		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2015	No	

5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2015

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 09/07/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

There are no Appendices included