

# Annual Environmental Report

2020



Banteer

D0448-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 BANTEER WWTP - 2020 - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - BANTEER WWTP - 2020
  - 2.1.2 EFFLUENT MONITORING SUMMARY - BANTEER WWTP - 2020 -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR BANTEER WWTP - 2020
  - 2.1.5 SLUDGE/OTHER INPUTS TO BANTEER WWTP - 2020

### **3 COMPLAINTS SUMMARY**

- 3.1 REPORTED INCIDENTS SUMMARY
  - 3.1.1 SUMMARY OF INCIDENTS
  - 3.1.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PEARL MUSSEL REPORT
- 5.2 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0448-01, Banteer, in Cork in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no major capital or operational changes undertaken

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Banteer WWTP - 2020 with a Plant Capacity PE of 550, the treatment type is 2 - Secondary treatment

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
<b>TPEFF0500D0448SW001</b>	Banteer WWTP - 2020	Treated	Non-Compliant	Suspended Solids mg/l

## 1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
<b>There are no Licence Specific Reports included in the AER.</b>	

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 BANTEER WWTP - 2020 - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - BANTEER WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	7	4.47	1.01
COD-Cr mg/l	7	618	109.82
Total Nitrogen mg/l	7	39.8	11.47
BOD, 5 days with Inhibition (Carbonaceo mg/l	7	180	38.01
Hydraulic Capacity	N/A	1208	391

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0500D0448SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	11	N/A	N/A	40.96	Pass
<b>Suspended Solids mg/l</b>	25	62.5	N/A	11	3	1	23.28	Fail
<b>BOD, 5 days with Inhibition (Carbonaceous) mg/l</b>	25	50	N/A	10	N/A	N/A	8.94	Pass
<b>pH pH units</b>	9	9	N/A	11	N/A	N/A	7.69	Pass
<b>Ammonia-Total (as N) mg/l</b>	5	6	N/A	11	N/A	N/A	1.12	Pass
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	5	6	N/A	11	N/A	N/A	0.72	Pass
<b>Total Nitrogen mg/l</b>	N/A	N/A	N/A	10	N/A	N/A	11.55	
<b>Total Phosphorus (as P) mg/l</b>	N/A	N/A	N/A	10	N/A	N/A	0.95	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

### Cause of Exceedance(s):

The ELV exceedances on 27/08/2020 and 16/09/2020 are associated with carryover of solids from the surface of the Settlement Tank as there is no dedicated Sludge Holding Tank or facility for the removal of scum from the surface of the existing Settlement Tank at present. The ELV exceedance on 11/11/2020 is as a result of heavy rainfall associated with a Yellow Rainfall Alert which gave rise to large inflows due to combined nature of collection network. This resulted in increased upward velocity in the Final Settlement Tank which in turn resulted in some carryover of suspended solids.

### Significance of Results:

The WWTP is non-compliant with the ELV's set in the Wastewater Discharge Licence. The impact on the receiving waters is assessed further in Section 2.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0500D0448SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	138236, 98765	RS18B021000	No	No	Yes	No	Good
Downstream	144272, 98874	RS18B021200	No	No	Yes	No	Good

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
<b>BOD - 5 days (Total) mg/l</b>	RS18B021000	0.9	RS18B021200	0.96	1.3	4.3
<b>Ammonia-Total (as N) mg/l</b>	RS18B021000	0.03	RS18B021200	0.02	0.04	-2.2
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	RS18B021000	0.02	RS18B021200	0.02	0.03	6
<b>Nitrate (as N) mg/l</b>	RS18B021000	1.47	RS18B021200	1.68		
<b>Temperature °C</b>	RS18B021000	12.76	RS18B021200	12.81		
<b>Conductivity @25°C µS/cm</b>	RS18B021000	154	RS18B021200	208.5		
<b>Chloride mg/l</b>	RS18B021000	18.25	RS18B021200	21.08		
<b>True Colour mg/litre Pt Co</b>	RS18B021000	49.5	RS18B021200	41.5		
<b>Dissolved Oxygen % O2</b>	RS18B021000	100.6	RS18B021200	99.4		
<b>Alkalinity-total (as CaCO3) mg/l</b>	RS18B021000	36.5	RS18B021200	58.5		
<b>Dissolved Oxygen % Saturation</b>	RS18B021000	101.25	RS18B021200	99.5		
<b>Nitrite (as N) µg/l</b>	RS18B021000	2.83	RS18B021200	7.29		
<b>pH pH units</b>	RS18B021000	7.54	RS18B021200	7.63		



Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
<b>Total Oxidised Nitrogen (as N) mg/l</b>	RS18B021000	1.47	RS18B021200	1.68		
<b>Dissolved Oxygen mg/l</b>	RS18B021000	10.6	RS18B021200	10.48		
<b>Total Hardness (as CaCO3) mg/l</b>	RS18B021000	45.25	RS18B021200	67.25		
<b>Orthophosphate (as P) - filtered mg/l</b>	RS18B021000	0.04	RS18B021200	0.03		
<b>Conductivity @20°C µS/cm</b>	RS18B021000	136	RS18B021200	180		
<b>Nitrite (as N) mg/l</b>	RS18B021000	0	RS18B021200	0.01		

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD & Ortho-P, concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are: Catchment Pressures

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - BANTEER WWTP - 2020

### 2.1.4.1 Treatment Efficiency Report - Banteer WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
cBOD	8022	1434	82
TN	2422	1851	24
TP	213	152	29
COD	23180	6751	71
SS	N/A	3836	N/A

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - Banteer WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Banteer WWTP - 2020	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	483
DWF to the Treatment Plant (m <sup>3</sup> /day)	161
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	1208

Banteer WWTP - 2020	
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	391
Organic Capacity (PE) - As Constructed	550
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	423
Organic Capacity (PE) - Remaining	127
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - BANTEER WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>There is no Sludge and Other Input data for the Treatment Plant included in the AER.</b>							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2020.			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	WWTP upgrade required to meet ELV	1	Yes	No
Breach of ELV	Other	1	No	No
Abatement Equipment offline	EO caused by power failure	1	No	No

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	4
Number of Incidents reported to the EPA via EDEN in 2020	4
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
<b>TBC</b>	139158, 98376	No	Low	Unknown	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	Yes

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>There are no Specified Improvement Programmes for this Agglomeration.</b>							

A summary of the status of any improvements identified by under Condition 5.2 is included below.

### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

### 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

N/A

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
<b>Pearl Mussel Report</b>	Yes	2014	No	
<b>Priority Substances Assessment</b>	Yes	2014	No	

### 5.1 PEARL MUSSEL REPORT

The Pearl Mussel Report Report has been included in the AER 2014

### 5.2 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2014



## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	Yes
List reason e.g. additional SWO identified	Additional SWO within confines of WWTP.
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	Yes
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 30/06/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

## **7 APPENDIX**

There are no Appendices included