

Annual Environmental Report

2020



Rathmullen

D0345-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 RATHMULLAN SEPTIC TANK NR. 2 - 2020 - UNTREATED DISCHARGE
 - 2.1.1 EFFLUENT MONITORING SUMMARY - RATHMULLAN SEPTIC TANK NR. 2 - 2020 -
 - 2.1.2 AMBIENT MONITORING SUMMARY FOR UNTREATED DISCHARGE -
- 2.2 RATHMULLAN SEPTIC TANK NR. 1 - 2020 - UNTREATED DISCHARGE
 - 2.2.1 EFFLUENT MONITORING SUMMARY - RATHMULLAN SEPTIC TANK NR. 1 - 2020 -
 - 2.2.2 AMBIENT MONITORING SUMMARY FOR UNTREATED DISCHARGE -

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

7.1 OTHER

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0345-01, Rathmullen, in Donegal in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

1.2 TREATMENT SUMMARY

- Currently there is no treatment provided at Rathmullen . Please refer to section 4 for details of the Programme of Improvements.
- Please note that the agglomeration has two septic tanks. However, from 2018 this agglomeration was considered untreated discharge with a plant capacity of 0 PE, due to the inadequate primary treatment provided.

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0600D0345SW002	Rathmullen Septic Tank Nr. 2 - 2020	Untreated	Non-Compliant	TSS, CBOD
TPEFF0600D0345SW001	RATHMULLAN SEPTIC TANK NR. 1 - 2020	Untreated	Non-Compliant	TSS, CBOD

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1.1 EFFLUENT MONITORING SUMMARY -

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Chemical Oxygen Demand mg/l	N/A	N/A	N/A	6	N/A	N/A	351	
Faecal coliforms cfu/100ml	N/A	N/A	N/A	4	N/A	N/A	N/A	
Ammonia-Total (as N) mg/l	N/A	N/A	N/A	6	N/A	N/A	16.65	
Nitrate (as N) mg/l	N/A	N/A	N/A	1	N/A	N/A	1.83	
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	6	N/A	N/A	2.08	
pH pH units	N/A	N/A	N/A	6	N/A	N/A	7.13	
Enterococci (Intestinal) cfu/100ml	N/A	N/A	N/A	4	N/A	N/A	483000	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Suspended Solids mg/l	N/A	N/A	50%	6	5	N/A	142.5	Fail
BOD, 5 days with Inhibition (Carbonaceous) mg/l	N/A	N/A	20%	6	1	N/A	125.33	Fail
Conductivity 20 C µS/cm	N/A	N/A	N/A	6	N/A	N/A	576.17	
E. Coli MPN/100ml	N/A	N/A	N/A	4	N/A	N/A	14802750	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

The agglomeration is not served by a wastewater treatment plant.

Significance of Results:

The WWTP is not compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.2 AMBIENT MONITORING SUMMARY FOR THE UNTREATED DISCHARGE TPEFF0600D0345SW002

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
There is no Ambient data included in the AER.							

Where the receiving water body is not a river or where the data is not in EDEN – the Ambient data will be appended.

Significance of Results:

The WWTP discharge was non-compliant with the ELV's set in the wastewater discharge licence.

It is unknown if the ambient monitoring points meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

It is unknown if discharge from the wastewater treatment plant has an observable impact on the water quality.

It is unknown if discharge from the wastewater treatment plant has an observable negative impact on the Water Framework Directive status.

2.1.3 EFFLUENT MONITORING SUMMARY -

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Faecal coliforms cfu/100ml	N/A	N/A	N/A	4	N/A	N/A	N/A	
Suspended Solids mg/l	N/A	N/A	50%	6	5	N/A	184.33	Fail
Nitrate (as N) mg/l	N/A	N/A	N/A	1	N/A	N/A	1.26	
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	6	N/A	N/A	4.37	
E. Coli MPN/100ml	N/A	N/A	N/A	4	N/A	N/A	7176747.69	
Conductivity @20°C µS/cm	N/A	N/A	N/A	6	N/A	N/A	662.91	
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	N/A	N/A	20%	6	5	N/A	209.07	Fail
Ammonia-Total (as N) mg/l	N/A	N/A	N/A	6	N/A	N/A	31.04	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Enterococci (Intestinal) cfu/100ml	N/A	N/A	N/A	4	N/A	N/A	248406.77	
pH pH units	N/A	N/A	N/A	6	N/A	N/A	8.01	
COD-Cr mg/l	N/A	N/A	N/A	6	N/A	N/A	566.87	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

The agglomeration is not served by a wastewater treatment plant

Significance of Results:

The WWTP is not compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.4 AMBIENT MONITORING SUMMARY FOR THE UNTREATED DISCHARGE TPEFF0600D0345SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Downstream	231780, 429809	CW06007072LS2001	Yes	No	No	Yes	Good

Where the receiving water body is not a river or where the data is not in EDEN – the Ambient data will be appended.

Significance of Results:

The WWTP discharge was non-compliant with the ELV's set in the Wastewater Discharge Licence.

It is unknown if the ambient monitoring points meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

It is unknown if discharge from the wastewater treatment plant has an observable impact on the water quality.

It is unknown if discharge from the wastewater treatment plant has an observable negative impact on the Water Framework Directive status.

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2020.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	WWTP upgrade required to meet ELV	1	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	1
Number of Incidents reported to the EPA via EDEN in 2020	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
There are no Storm Water Overflows in this Agglomeration.							

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	N/A
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0345-SIP:01	Install UV or appropriate disinfection on the discharge	C	31/12/2015	Yes	At Planning Stage	31/12/2025	
D0345-SIP:02	Primary Discharge Point SW001 to be discontinued	C	31/12/2015	Yes	At Planning Stage	31/12/2025	
D0345-SIP:03	Provide a wastewater treatment plant providing secondary treatment to ensure compliance with ELVs as specified in the RL	C	31/12/2015	Yes	At Planning Stage	31/12/2025	
D0345-SIP:04	Secondary Discharge Point SW002 to be discontinued	C	31/12/2015	Yes	At Planning Stage	31/12/2025	

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

N/A

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2015	No	

5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2015

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 22/03/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Other

Category	MONTH	Location	Lab Ref	Date	Ammor	BOD	Chloro	Dissolved Inorganic Nitrogen (as N)
Coastal Wa	May	Rathmullan	202501745	13-May-20	NT	<2	NT	NT
Coastal Wa	June	Rathmullan	202502131	10-Jun-20	NT	<2	NT	NT

Dissolved Oxygen % Saturation	E coli	Intestinal Enterococci	Faecal Coliforms (E. coli)	Orthophos	Tempe	Total Oxidi	Total Nitro	Salinity	pH	SS
102.2	<1	3	<1	0.11	11.1	NT	NT	34.9	8.28	121
100.7	0	1	1	<0.02	12.1	NT	NT	34.6	8.02	139