

# Annual Environmental Report

2021



Tullamore

D0039-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2021 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 TULLAMORE WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - TULLAMORE WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - TULLAMORE WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR TULLAMORE WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO TULLAMORE WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2021 AER

This Annual Environmental Report has been prepared for D0039-01, Tullamore, in Offaly in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works, significant changes or operational improvements undertaken in 2021.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- TULLAMORE WWTP with a Plant Capacity PE of 45000, the treatment type is 3P - Tertiary P removal.

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2500D0039SW001	TULLAMORE WWTP	Treated	Compliant	N/A

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

**There are no Licence Specific Reports included in this AER.**

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 TULLAMORE WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - TULLAMORE WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	16	33	9.48
pH pH units	12	7.77	7.18
Total Nitrogen mg/l	16	180	51
ortho-Phosphate (as P) - unspecified mg/l	12	9.30	3.43
BOD, 5 days with Inhibition (Carbonaceous) mg/l	16	15510	1869
COD-Cr mg/l	16	21100	3037.84
Suspended Solids mg/l	16	69700	5666.99
Ammonia-Total (as N) mg/l	12	36	24
Hydraulic Capacity	N/A	16500	10667

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

## Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

### 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2500D0039SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	16	N/A	N/A	20	Pass
<b>Suspended Solids mg/l</b>	15	38	N/A	16	N/A	N/A	4.13	Pass
<b>pH pH units</b>	6.00	9.00	N/A	16	N/A	N/A	7.75	Pass
<b>BOD, 5 days with Inhibition (Carbonaceous) mg/l</b>	8.00	16	N/A	16	N/A	N/A	1.56	Pass
<b>Ammonia-Total (as N) mg/l</b>	0.500	1.00	N/A	16	N/A	N/A	0.108	Pass
<b>Total Phosphorus (as P) mg/l</b>	0.500	0.600	N/A	16	1	N/A	0.236	Pass
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	0.250	0.500	N/A	16	N/A	N/A	0.095	Pass

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Nitrite (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	0.067	
Conductivity @20°C µS/cm	N/A	N/A	N/A	12	N/A	N/A	1362	
Nitrate (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	27	
Total Nitrogen mg/l	N/A	N/A	N/A	13	N/A	N/A	28	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Not applicable

### Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2500D0039SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	233276, 224875	RS25T030300	No	No	No	No	Unassigned
Downstream	229513, 225049	RS25T030400	No	No	No	No	Moderate

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS25T030300	0.766	RS25T030400	1.08	1.50	21.1
Ammonia-Total (as N) mg/l	RS25T030300	0.032	RS25T030400	0.037	0.065	8.3
ortho-Phosphate (as P) - unspecified mg/l	RS25T030300	0.024	RS25T030400	0.040	0.035	45.7
Dissolved Oxygen % Saturation	RS25T030300	79	RS25T030400	83	N/A	



Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Conductivity @25°C µS/cm	RS25T030300	743	RS25T030400	829	N/A	
Total Oxidised Nitrogen (as N) mg/l	RS25T030300	2.78	RS25T030400	5.46	N/A	
Dissolved Oxygen mg/l	RS25T030300	8.76	RS25T030400	9.18	N/A	
Total Hardness (as CaCO3) mg/l	RS25T030300	415	RS25T030400	409	N/A	
Alkalinity-total (as CaCO3) mg/l	RS25T030300	348	RS25T030400	337	N/A	
pH pH units	RS25T030300	8.06	RS25T030400	7.96	N/A	
Nitrite (as N) µg/l	RS25T030300	14	RS25T030400	16	N/A	
Nitrate (as N) mg/l	RS25T030300	2.78	RS25T030400	5.44	N/A	
Chloride mg/l	RS25T030300	24	RS25T030400	46	N/A	
Temperature °C	RS25T030300	11	RS25T030400	12	N/A	
True Colour mg/litre Pt Co	RS25T030300	44	RS25T030400	35	N/A	

### Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS at the downstream monitoring location. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD, Ammonia & Ortho-P concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

As per the 3rd Cycle Lower Shannon (Brosna) Catchment Report (HA 25A), the significant pressure on the At Risk Tullamore\_040 waterbody is Urban Runoff. The Tullamore WWTP although listed on Cycle 2 as a significant pressure has been removed from the list of significant pressures in the Cycle 3 report.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - TULLAMORE WWTP

### 2.1.4.1 Treatment Efficiency Report - TULLAMORE WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	18584	522	97
SS	11111462	9127	100
TN	100129	65412	35
COD	5956394	44574	99
cBOD	3664590	3460	100

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - TULLAMORE WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

TULLAMORE WWTP	
<b>Peak Hydraulic Capacity (m<sup>3</sup>/day) - As Constructed</b>	33000
<b>DWF to the Treatment Plant (m<sup>3</sup>/day)</b>	11000
<b>Current Hydraulic Loading - annual max (m<sup>3</sup>/day)</b>	16500
<b>Average Hydraulic loading to the Treatment Plant (m<sup>3</sup>/day)</b>	10667
<b>Organic Capacity (PE) - As Constructed</b>	45000
<b>Organic Capacity (PE) - Collected Load (peak week)<sup>Note1</sup></b>	22603
<b>Organic Capacity (PE) - Remaining</b>	22397
<b>Will the capacity be exceeded in the next three years? (Yes/No)</b>	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - TULLAMORE WWTP

'Other inputs' to the waste water treatment plant are summarised in table below.

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>Landfill Leachate (delivered by tanker)</b>	15432.80	Volume (m <sup>3</sup> )	276	0.58	Yes	Yes	Yes
<b>Waterworks (WWTP) Sludge</b>	22673.00	Weight (Tonnes)	188	0.40	Yes	Yes	Yes
<b>Industrial / Commercial Sludge</b>	4853.80	Weight (Tonnes)	59	0.13	Yes	Yes	Yes

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2021.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>Abatement Equipment offline</b>	Dosing pump failure or maintenance at WWTP	1	No	Yes

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2021	1
Number of Incidents reported to the EPA via EDEN in 2021	1
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2021 (No. of events)	Total volume discharged in 2021 (m <sup>3</sup> )	Monitoring Status
TBC	234928, 225301	No	Medium	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	TBC, TBC	No	Medium	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	TBC, TBC	No	Medium	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	234273, 225431	No	Medium	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	233756, 225070	No	Medium	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	234691, 223785	No	Medium	Meeting	Unknown	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2021 (No. of events)	Total volume discharged in 2021 (m <sup>3</sup> )	Monitoring Status
<b>TBC</b>	233045, 224853	No	Medium	Not yet Assessed	Unknown	Unknown	Not Monitored
<b>TBC</b>	TBC, TBC	No	Medium	Not yet Assessed	Unknown	Unknown	Not Monitored
<b>SW002</b>	232859, 224820	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
<b>SW002</b>	232859, 224820	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
<b>SW003</b>	235074, 225080	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
<b>SW004</b>	233175, 226540	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
<b>SW005</b>	233238.2, 224887.2	Yes	Medium	Not yet Assessed	Unknown	Unknown	Not Monitored
<b>SW007</b>	233445, 224836	Yes	Medium	Not yet Assessed	Unknown	Unknown	Not Monitored
<b>SW010</b>	234224, 224931	Yes	Medium	Not yet Assessed	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.



### SWO Summary

How much sewage was discharged via monitored SWOs in the agglomeration in the year (m <sup>3</sup> )?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NAY)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0039-SIP:01</b>	Construction of the proposed secondary discharge outfall to the Clodiagh River for p.e. in excess of 30,000, and not greater than 15,000	C	01/01/2012	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period.
<b>D0039-SIP:02</b>	De-commissioning of secondary discharge SW14 (SW002)	C	01/01/2014	Yes	Works Completed		
<b>D0039-SIP:03</b>	De-commissioning of SW003 storm water overflow	C	01/01/2012	Yes	Works Completed		

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0039-SIP:04</b>	De-commissioning of SW004 storm water overflow	C	01/01/2014	Yes	Works Completed		
<b>D0039-SIP:05</b>	De-commissioning of SW005 storm water overflow	C	01/01/2012	Yes	Works Completed		
<b>D0039-SIP:06</b>	De-commissioning of SW007 storm water overflow	C	01/01/2014	Yes	Works Completed		
<b>D0039-SIP:07</b>	Discharge to cease: SW003 to Tullamore River	A	01/01/2012	Yes	Works Completed		
<b>D0039-SIP:08</b>	Discharge to cease: SW004 to Tullamore River	A	01/01/2014	Yes	Works Completed		
<b>D0039-SIP:09</b>	Discharge to cease: SW005 to Tullamore River	A	01/01/2012	Yes	Works Completed		
<b>D0039-SIP:10</b>	Installation of storm water storage tank at the inlet of the works	C	01/01/2012	Yes	Works Completed		
<b>D0039-SIP:11</b>	SW002 to Tullamore River to be discontinued (formerly SW14)	A	01/01/2014	Yes	Works Completed		

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0039-SIP:12</b>	SW007 to Tullamore River to be discontinued	A	01/01/2014	Yes	Works Completed		
<b>D0039-SIP:13</b>	Upgrade of the existing WWTP including the installation of storm water storage tank at the inlet of the works	C	01/01/2012	Yes	Works Completed		
<b>D0039-SIP:14</b>	Upgrading of SW10 to comply with DoE criteria for SWOs.	C	01/01/2014	Yes	Works Completed	31/12/2021	No works required. Deemed compliant under completed DAP.

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

#### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>No additional improvements planned at this time.</b>				

#### 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Priority Substances Assessment	Yes	2014	No

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e., have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Has a Technical amendment/licence review application been submitted to the Agency by IW?	No
List reason e.g., additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g., changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 22/04/2022

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

## 7 APPENDIX

There are no Appendices included.