

# Annual Environmental Report

2021



Enniskerry and Environs

D0088-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2021 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 ENNISKERRY AND ENVIRONS WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - ENNISKERRY AND ENVIRONS WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - ENNISKERRY AND ENVIRONS WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR ENNISKERRY AND ENVIRONS WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO ENNISKERRY AND ENVIRONS WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

- 7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2021 AER

This Annual Environmental Report has been prepared for D0088-01, Enniskerry and Environs, in Wicklow in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works, significant changes or operational improvements undertaken in 2021.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- ENNISKERRY AND ENVIRONS WWTP with a Plant Capacity PE of 6000, the treatment type is 3P - Tertiary P removal.

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF3400D0088SW001	ENNISKERRY AND ENVIRONS WWTP	Treated	Compliant	N/A

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

**There are no Licence Specific Reports included in this AER.**

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 ENNISKERRY AND ENVIRONS WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - ENNISKERRY AND ENVIRONS WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Nitrogen mg/l	12	82	44
Total Phosphorus (as P) mg/l	12	9.24	3.85
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	205	137
COD-Cr mg/l	12	444	285.85
Suspended Solids mg/l	12	173	115.54
Hydraulic Capacity	N/A	3317	822

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF3400D008SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	12	N/A	N/A	22	Pass
<b>Suspended Solids mg/l</b>	30	75	N/A	12	N/A	N/A	4.52	Pass
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	20	40	N/A	12	N/A	N/A	3.05	Pass
<b>pH pH units</b>	6.00	9.00	N/A	12	N/A	N/A	7.28	Pass
<b>Ammonia-Total (as N) mg/l</b>	3.00	3.60	N/A	12	N/A	N/A	0.668	Pass
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	1.00	1.20	N/A	12	N/A	N/A	0.291	Pass
<b>Total Nitrogen mg/l</b>	N/A	N/A	N/A	12	N/A	N/A	16	
<b>Faecal coliforms cfu/100ml</b>	N/A	N/A	N/A	2	N/A	N/A	N/A	
<b>Total Phosphorus (as P) mg/l</b>	N/A	N/A	N/A	12	N/A	N/A	0.370	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>Total Oxidised Nitrogen (as N) mg/l</b>	N/A	N/A	N/A	12	N/A	N/A	14	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Not applicable

### Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF3400D0088SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
<b>Upstream</b>	324343, 217074	RS10D010100	No	No	No	No	Good
<b>Downstream</b>	324354, 217111	RS10D010120	No	No	No	No	Moderate

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

### Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD, Ammonia & Ortho-P concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The Enniskerry agglomeration was listed as a pressure in the Cycle 2 Ovoca-Vartry Catchment Report (HA 10) but has been removed from the list of significant pressures in the Cycle 3 Report.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.



## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - ENNISKERRY AND ENVIRONS WWTP

### 2.1.4.1 Treatment Efficiency Report - ENNISKERRY AND ENVIRONS WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
<b>TN</b>	11763	5320	55
<b>SS</b>	31140	1521	95
<b>cBOD</b>	36944	1025	97
<b>TP</b>	1037	125	88
<b>COD</b>	77043	7356	90

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - ENNISKERRY AND ENVIRONS WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

ENNISKERRY AND ENVIRONS WWTP	
<b>Peak Hydraulic Capacity (m<sup>3</sup>/day) - As Constructed</b>	4050
<b>DWF to the Treatment Plant (m<sup>3</sup>/day)</b>	350
<b>Current Hydraulic Loading - annual max (m<sup>3</sup>/day)</b>	3317

ENNISKERRY AND ENVIRONS WWTP	
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	821.67
Organic Capacity (PE) - As Constructed	6000
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	2580
Organic Capacity (PE) - Remaining	3420
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - ENNISKERRY AND ENVIRONS WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Domestic /Septic Tank Sludge	49056	Volume (m <sup>3</sup> )	597	17	Yes	No	No

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2021.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>Abatement Equipment offline</b>	Adverse Weather	1	No	Yes

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2021	1
Number of Incidents reported to the EPA via EDEN in 2021	1
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	Total volume discharged in 2021 (m <sup>3</sup> )	Monitoring Status
SW002	324343.799, 217091.216	Yes	Low	Meeting	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m <sup>3</sup> )?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>There are no Specified Improvement Programmes for this Agglomeration.</b>							

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>No additional improvements planned at this time.</b>				

### 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Priority Substances Assessment	Yes	2011	No

### 5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2011.

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e., have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Has a Technical amendment/licence review application been submitted to the Agency by IW?	No
List reason e.g., additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g., changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A



I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 18/02/2022

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Katherine Walshe

Acting Head of Environmental Regulation.

## 7 APPENDIX

Appendix

**Appendix 7.1 - Ambient monitoring summary**

## Enniskerry 2021 Ambient Monitoring Summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)			
			Bathing Water	Drinking Water	FWPM	Shellfish
Upstream Monitoring Point	324343, 217074	RS10D010100	No	No	No	No
Downstream Monitoring Point	324354, 217111	RS10D010120	No	No	No	No

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Current WFD Status	cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream Monitoring Point	Good	0.850	0.0103	0.0246
Downstream Monitoring Point	Moderate	1.075	0.0165	0.0335
<i>Difference</i>		<i>0.225</i>	<i>0.006</i>	<i>0.009</i>
EQS		1.500	0.035	0.065
% of EQS		15.000%	17.857%	13.791%

## Enniskerry 2021 Ambient Monitoring Data

		Biological Oxygen Demand	Conductivity @ 20°C	Ortho-Phosphate P	Ammonium NH <sub>4</sub> -N	Total Oxidised Nitrogen N	Dissolved Oxygen	Nitrite N	pH	Dissolved Oxygen % Saturation	Temperature	Faecal Coliforms
Station	Sample Date	mg/l	µS/cm	mg/l	mg/l	mg/l	mg/l	mg/l	pH units	% O2	Degrees C	no./100mls
Br U/S Glencullen (U/S Enniskerry Wwtp)	20-Jan-21	0.9	92	0.012	<0.02	0.5	11.7	<0.005	7.7	98	7.3	59
Br U/S Glencullen (U/S Enniskerry Wwtp)	13-Apr-21	0.7	191	<0.01	<0.02	0.4	13.1	<0.005	8.1	110	7.9	67
Br U/S Glencullen (U/S Enniskerry Wwtp)	03-Aug-21	1	195	0.01	0.03	0.5	10.6	<0.005	7.9	102	13.4	261
Br U/S Glencullen (U/S Enniskerry Wwtp)	05-Oct-21	0.8	170	0.012	0.04	0.2	11.2	<0.005	7.9	99	10	387
	<b>Mean</b>	<b>0.85</b>	<b>162.00</b>	<b>0.0103</b>	<b>0.0246</b>	<b>0.40</b>	<b>11.65</b>	<b>0.00</b>	<b>7.90</b>	<b>102.25</b>	<b>9.65</b>	<b>193.50</b>
	<b>95%ile</b>	<b>0.99</b>	<b>194.40</b>	<b>0.0120</b>	<b>0.0385</b>	<b>0.50</b>	<b>12.89</b>	<b>0.00</b>	<b>8.07</b>	<b>108.80</b>	<b>12.89</b>	<b>368.10</b>
Br D/S Glencullen R Confl (D/S Enniskerry Wwtp)	20-Jan-21	1	108	0.012	<0.02	0.6	11.6	<0.005	7.7	97	7.9	78
Br D/S Glencullen R Confl (D/S Enniskerry Wwtp)	13-Apr-21	1.2	262	<0.01	0.03	0.8	13.1	0.006	8.3	112	8.4	488
Br D/S Glencullen R Confl (D/S Enniskerry Wwtp)	03-Aug-21	1.2	291	0.019	0.04	1.3	10.7	0.005	8	102	13.3	1120
Br D/S Glencullen R Confl (D/S Enniskerry Wwtp)	05-Oct-21	0.9	273	0.028	0.05	0.9	11	0.012	8	99	10.4	488
	<b>Mean</b>	<b>1.08</b>	<b>233.50</b>	<b>0.0165</b>	<b>0.0335</b>	<b>0.90</b>	<b>11.60</b>	<b>0.01</b>	<b>8.00</b>	<b>102.50</b>	<b>10.00</b>	<b>543.50</b>
	<b>95%ile</b>	<b>1.20</b>	<b>288.30</b>	<b>0.0267</b>	<b>0.0485</b>	<b>1.24</b>	<b>12.88</b>	<b>0.01</b>	<b>8.26</b>	<b>110.50</b>	<b>12.87</b>	<b>1025.20</b>

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations.