

Annual Environmental Report

2022



Enniscrone

D0102-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 ENNISCRONE WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - ENNISCRONE WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - ENNISCRONE WWTP -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR ENNISCRONE WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO ENNISCRONE WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 5.2 TOXICITY OF FINAL EFFLUENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

This Annual Environmental Report has been prepared for D0102-01, Enniscrone, in Sligo in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There are no major capital or operational changes undertaken.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Enniscrone WWTP with a Plant Capacity PE of 5000, the treatment type is 2 - Secondary treatment .

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2700D0102SW001	Enniscrone WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l Total Oxidised Nitrogen (as N) mg/l

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 ENNISCRONE WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - ENNISCRONE WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	25	18	4.45
COD-Cr mg/l	25	1142	296
Suspended Solids mg/l	25	880	136
BOD, 5 days with Inhibition (Carbonaceo mg/l	25	307	98
Total Nitrogen mg/l	25	122	35
Hydraulic Capacity	N/A	3928	863

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2700D0102SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	27	N/A	N/A	20	Pass
Suspended Solids mg/l	35	87.5	N/A	27	N/A	N/A	6.20	Pass
Temperature °C	25	25	N/A	26	N/A	N/A	11	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	25	50	N/A	27	N/A	N/A	2.23	Pass
Total Oxidised Nitrogen (as N) mg/l	15	18	N/A	26	1	1	8.74	Fail
Ammonia-Total (as N) mg/l	10	12	N/A	27	7	5	3.45	Fail
pH pH units	9	9	N/A	27	N/A	N/A	7.41	Pass
Fats, Oils & Greases mg/l	N/A	N/A	N/A	1	N/A	N/A	1.00	
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	1	N/A	N/A	1.64	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Refer to Incident Section of the Report

Significance of Results:

The WWTP is non complaint with the ELV's set in the Wastewater Discharge License. The impact on receiving waters is assessed further in Section 2.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2700D0102SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

Significance of Results:

The coastal/transitional ambient monitoring results do not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: Total Oxidised Nitrogen (as N) mg/l, Ammonia-Total (as N) mg/l.

A deterioration in water quality has been identified, however it is not known if it is or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

The discharge from the wastewater treatment plant does not have an observable impact on the bathing water quality.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - ENNISCRONE WWTP

2.1.4.1 Treatment Efficiency Report - Enniscrone WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	1121	N/A	N/A
TN	8771	N/A	N/A
COD	74610	4976	93
SS	34371	1534	96
cBOD	24725	551	98

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - Enniscrone WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Enniscrone WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	3369
DWF to the Treatment Plant (m ³ /day)	1123
Current Hydraulic Loading - annual max (m ³ /day)	3928
Average Hydraulic loading to the Treatment Plant (m ³ /day)	863
Organic Capacity (PE) - As Constructed	5000
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	3429
Organic Capacity (PE) - Remaining	1571
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - ENNISCRONE WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2022.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	Yes
Breach of ELV	WWTP not designed for N removal	1	Yes	Yes
Other	Broken Sewer Pipe	1	No	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2022	3
Number of Incidents reported to the EPA via EDEN in 2022	3
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2022 (No. of events)	Total volume discharged in 2022 (m3)	Monitoring Status
SW002	128488,330962	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
SW003	128358,329720	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
SW004	128448,331331	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m3)?	31687
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes

SWO Summary

Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?

N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
---	-------------	------------------	-------------------------	------------------------	-----------------	-----------------------------------	----------

There are no Specified Improvement Programmes for this Agglomeration.

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
------------------------	---	--------------------	--------------------------	----------

No additional improvements planned at this time.

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Priority Substances Assessment	Yes	2012	No
Toxicity of Final Effluent	Yes	2012	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 08/05/2023

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

Ambient Monitoring Report Summary Data

Ambient monitoring point/Coastal Monitoring Code	Irish Grid Reference	Designations				
		Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
TPEFF2700D105SW001	128,260mE, 329,920m N	YES	NO	NO	NO	Not at Risk

Ambient Monitoring Results Summary

Monitoring point	Date	Ammonia N	BOD	Chlorophyll	Dissolved Inorganic Nitrogen	Dissolved Oxygen	E. Coli	Enterococci	Faecal Coliforms	Nitrate	Nitrite	pH	Temperature	Total Oxidised Nitrogen
		mg/l	mg/l	ug/l	mg/l	mg/l	MPN/100mls	MPN/100mls	MPN/100mls	mg/l	mg/l	pH unit	Deg C	mg/l
CW22005295MY2010	27/01/2022	0.452	1.2	6.8	0.2	11.04				1	0.005	7.8	3.8	1
CW22005295MY2010	11/02/2022	0.324	1	8.1	0.2	11.21				1	0.005	7.8	7.4	1
CW22005295MY2010	08/03/2022	0.05	1	2.7	0.5	11.1				1	0.005	7.5	7.5	1
CW22005295MY2010	21/04/2022	0.48	3.5	22.2	0.5	11.6	1	1	1	1	0.005	8	9.9	1
CW22005295MY2010	20/05/2022	0.41	1.3	37	0.4	11.5				1	0.005	8	8.1	1
CW22005295MY2010	15/06/2022	0.48	1.3	1.3	0.2	13.32	1	1	5	1	0.005	8.3	14.7	1
CW22005295MY2010	12/07/2022	0.15	1.5	7.8	0.5	10.05	18	140	4	1	0.005	7.8	15.2	1
CW22005295MY2010	16/08/2022	0.45	1.4	15.2	0.5	9.7	8	16	25	1	0.005	7.9	19.8	1
CW22005295MY2010	07/09/2022	0.05	80.1	1.7	0.5	10.1				1	0.005	7.9	14.8	1
CW22005295MY2010	12/10/2022	0.44	2.3	16.7	0.5	9.8				1	0.005	8.1	14.6	1
CW22005295MY2010	24/10/2022	0.484	1.6	5.5	0.6	11.2	5	45	100	1	0.005	8	4.3	1
CW22005295MY2010	02/11/2022	0.45	1	5.5	0.5	8.9	50	29	1	1	0.005	8	13.5	1
CW22005295MY2010	10/11/2022	0.05	1.2	0.6	0.2	10.6	9	16	74	1	0.005	7.8	3.5	1
CW22005295MY2010	07/12/2022	0.47	1	6.6	0.2	9.3				1	0.005	8	4	1

Bathing Water Results Summary (if relevant)

Monitoring point	Date	Colour (Apparant)	Dissolved Oxygen	E Coli	Enterococci	pH	Salinity	Temperature
		Hazen	% O2	MPN/100mls	cfu/100mls	pH units	ppt	Deg C
BPBLF270000010002	23/05/2022	21.3	98.9	10	< 1	8.3	29.7	13.4
BPBLF270000010002	07/06/2022	11.5	106.1	< 10	< 1	8.3	34	14.2
BPNBF270000010102	07/06/2022	36.9	122.9	560	15	8.3	< 1	16.8
BPNBF270000010100	07/06/2022	12.6	114.9	< 10	< 1	8.4	33.6	13.5
BPBLF270000010002	20/06/2022	38.8	100.5	10	7	8.3	31.7	13.8

BPBPF270000010102	20/06/2022	47.7	104.3	410	37	8.4	< 1	14.4
BPBPF270000010100	20/06/2022	30.8	111.7	10	1	8.3	31.7	14
BPBPF270000010002	04/07/2022	40.3	104.5	10	1	8.3	28.2	14.5
BPBPF270000010102	04/07/2022	70.6	104.1	500	18	8.5	< 1	14.5
BPBPF270000010100	04/07/2022	29.1	106.5	< 10	3	8.2	29.4	14.7
BPBPF270000010002	18/07/2022	12.6	99.4	< 10	4	8.2	33	17.7
BPBPF270000010100	18/07/2022	23.5	137.6	10	30	8.4	32.3	19.5
BPBPF270000010102	18/07/2022	40.9	124.1	500	100	8.4	< 1	20.3
BPBPF270000010100	02/08/2022	30.1	116.5	140	15	8.2	30.7	17.9
BPBPF270000010102	02/08/2022	48.4	114.5	2010	390	8.4	< 1	18
BPBPF270000010002	02/08/2022	20.3	105.9	140	22	8.2	32.3	17.6
BPBPF270000010100	08/08/2022	10	100.4	< 10	1	8.1	32.9	15.9
BPBPF270000010102	08/08/2022	33.4	118.2	700	121	8.3	< 1	16.3
BPBPF270000010002	08/08/2022	28.5	99.9	< 10	< 1	8.1	34.4	16.3
BPBPF270000010002	15/08/2022	24.3	105.6	20	5	8.1	33.5	17.8
BPBPF270000010102	15/08/2022	36.3	105.6	310	160	8.3	< 1	17.2
BPBPF270000010100	15/08/2022	37.9	95.1	80	21	8.1	33.2	18.2
BPBPF270000010102	29/08/2022	38.2	140	190	50	8	< 1	19
BPBPF270000010100	29/08/2022	30.1	115.9	< 10	2	8.1	33	18.3
BPBPF270000010002	29/08/2022	27.5	99.1	< 10	1	8.2	33	18.4
BPBPF270000010100	12/09/2022	26.6	126.9	10	4	8.2	32.8	17.2
BPBPF270000010002	12/09/2022	36.6	102.6	20	11	8.1	33.2	16.8
BPBPF270000010102	12/09/2022	40.2	119.4	110	83	8.3	< 1	16.8