

# Annual Environmental Report

2022



Ballyshannon

D0128-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 BALLYSHANNON WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - BALLYSHANNON WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - BALLYSHANNON WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR BALLYSHANNON WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO BALLYSHANNON WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

This Annual Environmental Report has been prepared for D0128-01, Ballyshannon, in Donegal in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There are no major capital or operational changes undertaken.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Ballyshannon WWTP with a Plant Capacity PE of 6100, the treatment type is 2 - Secondary treatment .

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0600D0128SW001	Ballyshannon WWTP	Treated	Compliant	N/A

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

**There are no Licence Specific Reports included in this AER.**

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 BALLYSHANNON WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - BALLYSHANNON WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
COD-Cr mg/l	12	410	124
Total Phosphorus (as P) mg/l	12	6.95	3.09
BOD, 5 days with Inhibition (Carbonaceo mg/l	12	212	72
pH pH units	12	7.70	7.45
Suspended Solids mg/l	12	210	78
Ammonia-Total (as N) mg/l	12	38	20
ortho-Phosphate (as P) - unspecified mg/l	12	4.48	2.34
Total Nitrogen mg/l	12	53	26
Hydraulic Capacity	N/A	5510	1277

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

## Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

### 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0600D0128SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	12	N/A	N/A	18	Pass
<b>Suspended Solids mg/l</b>	30	75	N/A	12	1	N/A	7.29	Pass
<b>Temperature °C</b>	25	25	N/A	12	N/A	N/A	4.78	Pass
<b>BOD, 5 days with Inhibition (Carbonaceous) mg/l</b>	20	40	N/A	12	N/A	N/A	1.28	Pass
<b>pH pH units</b>	9	9	N/A	12	N/A	N/A	7.51	Pass
<b>Ammonia-Total (as N) mg/l</b>	5	6	N/A	12	N/A	N/A	0.472	Pass
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	N/A	N/A	N/A	12	N/A	N/A	0.883	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Faecal coliforms cfu/100ml	N/A	N/A	N/A	3	N/A	N/A	2974	
Total Nitrogen mg/l	N/A	N/A	N/A	12	N/A	N/A	16	
Enterococci (Intestinal) cfu/100ml	N/A	N/A	N/A	3	N/A	N/A	1239	
Nitrite (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	0.114	
Phenols (Total) µg/l	N/A	N/A	N/A	5	N/A	N/A	122	
Nitrate (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	15	
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	12	N/A	N/A	0.984	
E. Coli MPN/100ml	N/A	N/A	N/A	3	N/A	N/A	4691	
Conductivity @20°C µS/cm	N/A	N/A	N/A	12	N/A	N/A	619	



Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>Total Oxidised Nitrogen (as N) mg/l</b>	N/A	N/A	N/A	12	N/A	N/A	15	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Not applicable

### Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0600D0128SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	185797, 361927	TW06007040ER1008	No	No	No	No	Good
Downstream	185567, 361985	TW06007040ER1009	No	No	No	No	Good

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

### Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - BALLYSHANNON WWTP

### 2.1.4.1 Treatment Efficiency Report - Ballyshannon WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	1177	379	68
TN	9876	6146	38

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
<b>COD</b>	47215	6944	85
<b>cBOD</b>	27596	494	98
<b>SS</b>	29845	2805	91

Note: The above data is based on sample results for the number of dates reported

### **2.1.4.2 Treatment Capacity Report Summary - Ballyshannon WWTP**

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

<b>Ballyshannon WWTP</b>	
<b>Peak Hydraulic Capacity (m<sup>3</sup>/day) - As Constructed</b>	3546
<b>DWF to the Treatment Plant (m<sup>3</sup>/day)</b>	1182
<b>Current Hydraulic Loading - annual max (m<sup>3</sup>/day)</b>	5510
<b>Average Hydraulic loading to the Treatment Plant (m<sup>3</sup>/day)</b>	1277
<b>Organic Capacity (PE) - As Constructed</b>	6100
<b>Organic Capacity (PE) - Collected Load (peak week)<sup>Note1</sup></b>	2905
<b>Organic Capacity (PE) - Remaining</b>	3195
<b>Will the capacity be exceeded in the next three years? (Yes/No)</b>	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - BALLYSHANNON WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>There is no Sludge and Other Input data for the Treatment Plant included in the AER.</b>							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2022.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>Uncontrolled release</b>	EO caused by ragging or blocking	1	No	No
<b>Uncontrolled release</b>	EO caused by pump failure	1	No	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2022	2
Number of Incidents reported to the EPA via EDEN in 2022	2
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2022 (No. of events)	Total volume discharged in 2022 (m3)	Monitoring Status
<b>SW6</b>	185829,361780	Yes	Low Significance	Meeting Criteria	Unknown	10465	Monitored
<b>SW005</b>	187322,361393	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	TBC
<b>TBC</b>	187486,361402	No	Low Significance	Meeting Criteria	Unknown	Unknown	TBC

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m3)?	10465
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes

## SWO Summary

Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?

N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
---	-------------	------------------	-------------------------	------------------------	-----------------	-----------------------------------	----------

**There are no Specified Improvement Programmes for this Agglomeration.**

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
------------------------	---	--------------------	--------------------------	----------

**No additional improvements planned at this time.**



### **4.2.3 SEWER INTEGRITY RISK ASSESSMENT**

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Priority Substances Assessment	Yes	2015	No

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 03/05/2023

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

# 7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

Month	Category	Entity	Station	Lab Ref	Date	Ammonia (as N)	BOD	Chlorophyll	Dissolved Inorganic Nitrogen (as N)	Dissolved Oxygen % Saturation	E coli
March	Coastal Water Body	Erne Estuary	Ballyshannon - Upstream	222501602	08-Mar-22	<0.02	<2	<4	0.75	95.3	4
March	Coastal Water Body	Erne Estuary	Ballyshannon - Downstream	222501603	08-Mar-22	<0.02	<2	<4	0.74	96.4	4
June	Transitional Water Body	Erne Estuary	Ballyshannon - Upstream	222502736	14-Jun-22	0.68	4	NT	<0.52	98	4
June	Transitional Water Body	Erne Estuary	Ballyshannon - Downstream	222502737	14-Jun-22	0.53	4	NT	<0.52	98.2	10
September	Transitional Water Body	Erne Estuary	Ballyshannon - Upstream	222503848	14-Sep-22	0.58	5	<4	0.65	101.4	50
September	Transitional Water Body	Erne Estuary	Ballyshannon - Downstream	222503849	14-Sep-22	0.67	4	<4	0.7	102.8	8
November	Transitional Water Body	Erne Estuary	Ballyshannon - Upstream	222504721	15-Nov-22	<0.02	2	NT	<0.52	96.5	29
November	Transitional Water Body	Erne Estuary	Ballyshannon - Downstream	222504722	15-Nov-22	<0.02	3	NT	<0.52	97	17

Intestinal Enterococci	Faecal Coliforms	Orthophosphate	Temperature	Total Oxidised Nitrogen N	Total Nitrogen N	Salinity	pH	Suspended Solids	Chlorophyll	COD Chemical Oxygen Demand
1	5	<0.02	NT	NT	1.21	NT	7.3	NT	NT	NT
0	5	0.08	NT	NT	1.21	NT	7.5	NT	NT	NT
8	4	<0.02	NT	NT	<0.5	NT	7.6	NT	20.19	NT
0	10	<0.02	NT	NT	<0.5	NT	7.6	NT	11.62	NT
0	921	<0.02	NT	NT	<0.5	NT	8.1	NT	<4	NT
0	397	<0.02	NT	NT	<0.5	NT	8.2	NT	<4	NT
9	46	0.05	NT	NT	1.15	NT	7.5	NT	<7	NT
10	40	0.15	NT	NT	1.16	NT	7.5	NT	<7	NT