# Annual Environmental Report





Ballyvaughan

D0327-01

#### **CONTENTS**

#### 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

#### 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 BALLYVAUGHAN WWTP UNTREATED DISCHARGE
  - 2.1.1 EFFLUENT MONITORING SUMMARY BALLYVAUGHAN WWTP -
  - 2.1.2 Ambient Monitoring Summary for Untreated Discharge -

#### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

#### 4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
- 4.2.1 Specified Improvement Programme Summary
- 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
- 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

#### 5 LICENCE SPECIFIC REPORTS

5.1 SHELLFISH IMPACT ASSESSMENT

#### 6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

#### 7 APPENDIX

7.1 Ambient monitoring summary

## **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER**

This Annual Environmental Report has been prepared for D0327-01, Ballyvaughan, in Clare in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## **1.1 ANNUAL STATEMENT OF MEASURES**

A summary of any improvements undertaken is provided where applicable.

There was no major capital or operational changes undertaken

## **1.2 TREATMENT SUMMARY**

• Currently there is no treatment provided at Ballyvaughan . Please refer to section 4 for details of the Programme of Improvements.

## **1.3 ELV OVERVIEW**

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0300D0327SW001	Ballyvaughan WWTP	Untreated	Non-Compliant	N/A

## **1.4 LICENCE SPECIFIC REPORTING**

Assessment / Report

There are no Licence Specific Reports included in this AER.

## **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

### 2.1.1 EFFLUENT MONITORING SUMMARY -

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
There is no	There is no Effluent data included in the AER.							

Notes:

1 - This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

#### **Cause of Exceedance(s):**

The agglomeration is not served by a wastewater treatment plant.

#### Significance of Results:

The ELVs set in the Wastewater Discharge Licence cannot be measured, as there is not influent or effluent data included in the AER.

#### 2.1.2 AMBIENT MONITORING SUMMARY FOR THE UNTREATED DISCHARGE TPEFF0300D0327SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Downstream	122875, 208383	CW03005223BG1001	No	No	No	No	High
Downstream	122657, 208507	CW03005223BG1002	No	No	No	Yes	High

The results for ambient results and / or additional monitoring data sets are included in the Appendix 7.1 - Ambient monitoring summary

#### **Significance of Results:**

The coastal/transitional ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: .

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

The discharge from the wastewater treatment plant does not have an observable impact on the coastal/transitional water quality.

## **3 COMPLAINTS AND INCIDENTS**

## **3.1 COMPLAINTS SUMMARY**

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

	Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2022.				

## **3.2 REPORTED INCIDENTS SUMMARY**

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### **3.2.1 SUMMARY OF INCIDENTS**

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
There were no reportable	incidents in 20			

#### **3.2.2 SUMMARY OF OVERALL INCIDENTS**

Question	Answer
Number of Incidents in 2022	0
Number of Incidents reported to the EPA via EDEN in 2022	0
Explanation of any discrepancies between the two numbers above	N/A

## **4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS**

### **4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT**

A summary of the operation of the storm water overflows and their significance where known is included below:

#### **4.1.1 SWO IDENTIFICATION**

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2022 (No. of events)	Total volume discharged in 2022 (m3)	Monitoring Status
There are no Storm Water Overflows in this Agglomeration.							

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	N/A
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

#### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0327-SIP:01	Upgrade the waste water works to provide primary treatment	С	31/12/2015	Yes	At Planning Stage	2025	Planning to be submitted Q2 23

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

#### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement	Improvement Description / or any Operational	Improvement	Expected Completion	Comments
Identifier	Improvements	Source	Date	
No additional improve	ments planned at this time.			

#### 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

N/A

## **5 LICENCE SPECIFIC REPORTS**

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Shellfish Impact Assessment	Yes		No

## **6 CERTIFICATION AND SIGN OFF**

## **6.1 SUMMARY OF AER CONTENTS**

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 12/06/2023

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

## **7 APPENDIX**

#### Appendix

Appendix 7.1 - Ambient monitoring summary

#### Ambient Monitoring Report Summary Data2022 BallyvaughanD0327

		Designations						
Ambient monitoring point/Coastal								
Monitoring Code	Irish Grid Reference	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status		
Ballyvaughan West; CW03005223BG1001	122875; 208383	No	No	No	Yes	Unassigned		
Ballyvaughan East; CW03005223BG1002	122657; 208507	No	No	No	Yes	Unassigned		

#### Ambient Monitoring Results Summary

		Biological Oxygen Demand	Ammonia N	рН	Suspended Solids	Total Oxidised Nitrogen N	Visual Inspection	Faecal Coliforms	Enterococci	E Coli
Monitoring Point	Date	mg/l	mg/l	pH units	mg/l	mg/l	Descriptive	no./100mls	cfu/100mls	no./100ml
							21-42 kph South Winds. 10c air temp. Large waves and			
CW03005223BG1002	21-Feb-2022	< 1	0.026	8	8	0.296	swell. Nothing unusual observed.	78	15	73
							17-22 km/h NW winds. Air temp 11.C No rain, 100% cloud			
CW03005223BG1002	30-May-2022	< 1	< 0.01	8.4	4	0.071	cover. Nothing unusual at site			
							17-22km/hr NW winds. 14c air temperature. Little cloud			
CW03005223BG1002	5-Aug-2022	< 1	< 0.01	8.1	26	0.075	cover, nothing unusual observed.	12	1	9
							Light rain, windy with gusts of 35km/hr winds from the			
							west. Sea waves with white caps. Could not launch the boat			
CW03005223BG1002 (53.122314-9.148147							from Balluvaughan due to high winds in the morning and			
surrogate site used unsafe to launch boat)	21-Nov-2022	<1	0.01	8.1	7	0.137	the sea being unortedictable.			

		Biological Oxygen Demand	Ammonia N	рН	Suspended Solids	Total Oxidised Nitrogen N	Visual Inspection	Faecal Coliforms	Enterococci	E Coli
Monitoring Point	Date	mg/l	mg/l	pH units	mg/l	mg/l	Descriptive	no./100mls	cfu/100mls	no./100mls
							21-42 kph S winds. 10C Air Temp. Large waves and swells.			1
CW03005223BG1001	21-Feb-2022	<1	< 0.01	8	15	0.297	Nothing unusual observed	91	9	72
							17-22 km/h NW winds. Air temp 11.C No rain,100% cloud			1
CW03005223BG1001	30-May-2022	1	< 0.01	8.4	6	0.019	cover. Nothing unusual at site			1
							17-22km/hr NW winds. 14c Air temperature. Nothing			1
CW03005223BG1001	5-Aug-2022	< 1	< 0.01	8.1	21	0.04	unusual observed.	2	< 1	1
Site inaccessible due to weather conditions surrogate site used see results under CW03005223BG1002										