Annual Environmental Report

2022



Ballymore Eustace

D0238-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 Treatment Summary
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 BALLYMORE EUSTACE NEW WWTP TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY BALLYMORE EUSTACE NEW WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY BALLYMORE EUSTACE NEW WWTP
 - 2.1.3 Ambient Monitoring Summary for The Treatment Plant Discharge
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR BALLYMORE EUSTACE NEW WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO BALLYMORE EUSTACE NEW WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 Summary of Overall Incidents

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 Specified Improvement Programme Summary
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 Priority Substances Assessment
- 5.2 SMALL STREAM RISK SCORE ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 Summary of AER Contents
- 7 APPENDIX

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

This Annual Environmental Report has been prepared for D0238-01, Ballymore Eustace, in Kildare in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works, significant changes or operational changes undertaken in 2022.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

• BALLYMORE EUSTACE NEW WWTP with a Plant Capacity PE of 2000, the treatment type is 3P - Tertiary P removal .

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1400D0238SW001	BALLYMORE EUSTACE NEW WWTP	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

Small Stream Risk Score Assessment

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 BALLYMORE EUSTACE NEW WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - BALLYMORE EUSTACE NEW WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	11	10	5.95
Ammonia-Total (as N) mg/l	11	90	56
BOD, 5 days with Inhibition (Carbonaceous) mg/l	11	245	158
ortho-Phosphate (as P) - unspecified mg/l	11	2.90	1.52
COD-Cr mg/I	11	1344	715
Suspended Solids mg/l	11	693	281
pH pH units	11	6.95	6.54
Hydraulic Capacity	N/A	304	131

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1400D0238SW000

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	11	N/A	N/A	19	Pass
Suspended Solids mg/l	35	88	N/A	11	N/A	N/A	5.80	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/I	25	50	N/A	11	N/A	N/A	2.37	Pass
pH pH units	6.00	9.00	N/A	11	N/A	N/A	6.25	Pass
Ammonia-Total (as N) mg/l	5.00	6.00	N/A	11	N/A	N/A	0.328	Pass
Total Phosphorus (as P) mg/l	2.00	2.40	N/A	11	N/A	N/A	0.526	Pass
ortho-Phosphate (as P) - unspecified mg/l	1.00	1.20	N/A	11	N/A	N/A	0.283	Pass

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Faecal coliforms MPN/100ml	N/A	N/A	N/A	6	N/A	N/A	5523	
Conductivity @20°C μS/cm	N/A	N/A	N/A	10	N/A	N/A	577	

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

^{1 –} This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied 2 – For pH the WWDA specifies a range of pH 6 - 9

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1400D0238SW000

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	292660, 209723	RS09L010400	No	No	No	No	Good
Downstream	292478, 209783	RS09L010500	No	No	No	No	Good

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS09L010400	0.766	RS09L010500	0.806	1.50	2.7
Ammonia-Total (as N) mg/l	RS09L010400	0.069	RS09L010500	0.065	0.065	-6.1
ortho-Phosphate (as P) - unspecified mg/l	RS09L010400	0.008	RS09L010500	0.007	0.035	-4
Nitrite (as N) μg/l	RS09L010400	6.21	RS09L010500	6.23	N/A	

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Dissolved Oxygen % Saturation	RS09L010400	98	RS09L010500	102	N/A	
Dissolved Oxygen mg/l	RS09L010400	10	RS09L010500	11	N/A	
Conductivity @25°C µS/cm	RS09L010400	170	RS09L010500	184	N/A	
Total Oxidised Nitrogen (as N) mg/l	RS09L010400	0.886	RS09L010500	0.948	N/A	
Alkalinity-total (as CaCO3) mg/l	RS09L010400	61	RS09L010500	67	N/A	
Nitrate (as N) mg/l	RS09L010400	0.882	RS09L010500	0.944	N/A	
pH pH units	RS09L010400	7.80	RS09L010500	7.88	N/A	
True Colour mg/litre Pt Co	RS09L010400	43	RS09L010500	44	N/A	
Chloride mg/l	RS09L010400	10	RS09L010500	11	N/A	
Temperature °C	RS09L010400	13	RS09L010500	13	N/A	
Total Hardness (as CaCO3) mg/l	RS09L010400	73	RS09L010500	81	N/A	

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD concentration downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it is or is not caused by the WWTP.

As per the 3rd Cycle Draft Liffey and Dublin Bay Catchment Report (HA 09), the significant pressures on the At Risk Liffey_050 waterbody are Agriculture, Domestic Waste Water & Hydromorphology

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - BALLYMORE EUSTACE NEW WWTP

2.1.4.1 Treatment Efficiency Report - BALLYMORE EUSTACE NEW WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)	
cBOD	6514	98	99	
ss	11600	239	98	
ТР	245	22	91	
COD	29459	800	97	

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - BALLYMORE EUSTACE NEW WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

BALLYMORE EUSTACE NEW WWTP					
Peak Hydraulic Capacity (m³/day) - As Constructed	1350				
DWF to the Treatment Plant (m³/day)					
Current Hydraulic Loading - annual max (m³/day)	304				
Average Hydraulic loading to the Treatment Plant (m³/day)					
Organic Capacity (PE) - As Constructed	2000				
Organic Capacity (PE) - Collected Load (peak week)Note1	844				
Organic Capacity (PE) - Remaining	1156				
Will the capacity be exceeded in the next three years? (Yes/No)	No				

Note 1: Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - BALLYMORE EUSTACE NEW WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)				
There is	There is no Sludge and Other Input data for the Treatment Plant included in the AER.										

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environme	ental complaints in 2022.		

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	No	Yes
Uncontrolled release SWO exceptional rainfall and overflow ex		1	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	No	Yes

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	No	Yes

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2022	4
Number of Incidents reported to the EPA via EDEN in 2022	4
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2022 (No. of events)	Total volume discharged in 2022 (m³)	Monitoring Status	
New SW2	Unknown	Yes	Low Significance	Meeting Criteria	Unknown	867	Monitored	

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m³)?	867
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0238-SIP:01	Discharges from SW1-P (existing WWTP discharge) to cease	А	31/12/2012	Yes	Works Completed		
D0238-SIP:02	SW2 - Upgrading of SWO to comply with the criteria outlined in the DoEHLG "Procedures and Criteria in relation to Storm Water Overflows, 1995".	С	31/12/2012	Yes	Works Completed		
D0238-SIP:03	SW3 - Upgrading of SWO to comply with the criteria outlined in the DoEHLG "Procedures and Criteria in relation to Storm Water Overflows, 1995".	С	31/12/2012	Yes	Works Completed		
D0238-SIP:04	Waste Water treatment plant and ancillary works	С	31/12/2012	Yes	Works Completed		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

	Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments	
No additional improvements planned at this time.						

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Priority Substances Assessment	Yes	2011	No
Small Stream Risk Score Assessment	Yes	2017	Yes

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 23/02/2023

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

7 APPENDIX

There are no Appendices included.



Ballymore Eustace Small Stream Risk Score 2022

Produced by

AQUAFACT International Services Ltd

For

Kildare County Council

November 2022

AQUAFACT INTERNATIONAL SERVICES Ltd., 12 KILKERRIN PARK, GALWAY.

www.aquafact.ie

info@aquafact.ie

tel +353 (0) 91 756812

Report Approval Sheet

Client	Kildare County Council
Report Title	Ballymore Eustace Small Stream Risk Score 2022
Job Number	JN1741
Report Status	Final
Issue Date	5 th December 2022

Rev	Status	Issue Date	Document File Name	Author (s)	Approved by:
1	Draft	30/11/2022	JN1741 Ballymore	Aaron Skehan	E. McCormack
			Eustace SSRS 2022		
2	Final	05/12/2022	JN1741 Ballymore	Aaron Skehan	E. McCormack
			Eustace SSRS 2022		
			Final		



Table of Contents

1.	Introduction	1
2.	Methodology	1
2.1. 2.2.	of the O	
3.	Results	3
4.	Ballymore Eustace WWTP comparison 2015 to 2022	4
5.	References	5
	List of Figures	
	Figure 2.1: Ballymore Eustace SSRS sampling sites.	2
	Figure 4.1: Ballymore Eustace WWTP SSRS scores 2015 to 2022	5
	List of Tables	
	Table 2.1: Ballymore Eustace SSRS station coordinates	3
	Table 2.2: SSRS Categories.	3
	Table 3.1: SSRS relative abundance of taxa	4
	Table 3.2: Biological sampling results	4
	Table 4.1: Ballymore Eustace WWTP- SSRS Comparison 2015 -2022	5

Appendices

Appendix 1: Photo log

Appendix 2: SSRS Data Sheets

Kildare County Council
November 2022

1. Introduction

AQUAFACT was contracted by Kildare County Council to carry out an SSRS assessment of the discharge belonging to Ballymore Eustace wastewater treatment plants. A sample was taken upstream and downstream of the discharge point. The sampling was carried out on the 25th of October 2022.

2. Methodology

2.1. Sampling

Two kick samples were taken (See Figure 2.1 and Table 2.1). The two-minute kick and one minute stone wash sampling method was employed to collect samples of macroinvertebrates for analysis. This involved placing a standard hand net of pore size 500µm in the river, facing upstream and disturbing the riverbed in front of the net mouth. The surveyor then moved in a diagonal direction upstream to ensure that different micro-habitats were included in the sample. Net sweepings of any submerged marginal plants were also conducted. The kick sample method dislodges macroinvertebrates from the substrates and submerged plant material. This was continued for approximately two minutes and followed by one minute of stone washing (Lucey *et al.*, 1999).

The macroinvertebrate assemblages of each sample were returned to the lab, preserved in 70% industrial methylated spirits, identified and enumerated. The details of the macroinvertebrate assemblages were recorded on data sheets. The resulting species list was then used to assign the SSRS score to the sampled streams.

The IFI's 2010 Biosecurity Protocol for Field Survey Work document was followed during sampling. Nets and all other equipment were thoroughly disinfected between stations.

Figure 2.1: Ballymore Eustace SSRS sampling sites.





Table 2.1: Ballymore Eustace SSRS station coordinates.

Station	Easting	Northing
Ballymore Eustace aSW1-PU	292154	210202
Ballymore Eustace aSW1-PD	292148	210304

2.2. Small Stream Risk Score

The Small Streams Risk Score (SSRS) is a biological risk assessment system for identifying rivers that are 'at risk' of failing to achieve the 'good' water quality status goals of the Water Framework Directive (WFD). It was developed by the Environmental Protection Agency (EPA) in association with the Western River Basin District (WRBD) in 2006 and revised in 2009.

The SSRS method is a rapid field methodology for risk assessment that is based solely on macroinvertebrate indicators of water quality and their well-understood response to pollution. Importantly, the SSRS score indicates whether or not the stream is at risk from pollution and is not a measurement of the ecological health of the stream. The SSRS score ranges from 0-11.2. Table 3.1 presents a list of the taxa recorded in each sample and their relative abundance.

Table 2.2: SSRS Categories.

SSRS range	Category
<6.5	Stream at Risk
>6.5-7.25	Indeterminate stream may be at risk
>7.25	Probably not at risk

3. Results

Table 3.1 presents a list of the taxa recorded in each sample and their relative abundance, and Table 3.2 presents the SSRS. The full SSRS data sheets and scoring are presented in Appendix 2. Both the upstream and downstream station were categorised as 'Probably not at Risk'. The river substrate was the same at both stations with a mix of boulders, cobbles and gravel. The flow in the river was torrential and the water very clear. There was no siltation present. The habitat is suitable for white-clawed crayfish although none were captured or observed during sampling.



Table 3.1: SSRS relative abundance of taxa

Таха	Upstream	Downstream
Trichoptera		
Limnephilidae	1	
Polycentropodidae	1	1
Hydropsychidae	5	5
Rhyacophila	1	3
Ephemeroptera		
Heptagenia	3	2
Plecoptera		
Leuctra	2	1
Gastropoda		
Ancylus	2	
Diptera		
Chironimidae	2	1
Tipulidae		1

Table 3.2: Biological sampling results.

Station	SSRS score	SSRS category
Ballymore Eustace aSW1-PU	8.0	Probably not at Risk
Ballymore Eustace aSW1-PD	8.0	Probably not at Risk

4. Ballymore Eustace WWTP comparison 2015 to 2022

Table 4.1 compares the SSRS results from 2015 to 2022 and Figure 4.1 displays the trend over time. The downstream station was categorised as 'Probably not at risk' in 2017, 2018, 2020, 2021 and 2022. The upstream station has an improved score, compared to the 'At risk' in 2021. However, the upstream station was 'Probably not at risk' in 2015, 2018 and 2020. Apart from 2019 the downstream station has been categorised as not at risk since 2017. In those years the downstream station has also recorded a higher SSRS score except for 2018.



Table 4.1: Ballymore	Fustace WWTP-	SSRS Compariso	n 2015 -2022
I apic 4.T. palivillole	LUSTACE AN AN IL-	SSNS CUIIDAIISU	II 7013 -7027

SSRS										S	SRS Risk	Catego	ry			
Site	2015	2016	2017	2018	2019	2020	2021	2022	2015	2016	2017	2018	2019	2020	2021	2022
U/S	8.0	3.2	5.6	9.6	n/a	8.0	4	8.0	PNAR	AR	AR	PNAR	n/a	PNAR	AR	PNAR
D/S	7.2	4.8	8.8	8.0	n/a	8.8	8.0	8.0	Indet.	AR	PNAR	PNAR	n/a	PNAR	PNAR	PNAR




Figure 4.1: Ballymore Eustace WWTP SSRS scores 2015 to 2022

5. References

EPA. 2015. Guidance on Application and Use of the SSRS in Enforcement of Urban Waste Water Discharge Authorisations in Ireland.

https://www.epa.ie/publications/compliance--enforcement/waste-water/SSRS-in-Enforcement-of-UWWDAs.pdf Accessed September 2021.

Lucey, J., Bowman, J.J., Klabby, K.J., Cunningham, P., Lehane, M., MacCarthaigh, M., McGarrigle, M.L. and Toner, P.F. 1999. Water Quality in Ireland, 1995 – 1997. EPA.



Appendix 1 Photo log



Ballymore Eustace upstream





Ballymore Eustace downstream

Appendix 2 SSRS Data Sheets




BALLYMORE EUSTACE UPSTREAM

River: LIFE	EY	Code:		Date:	25-10	-22		.45		
Station no.		Location:	BALLY	MORE E	USTAC	Ε	Grid (6 figure):			
UPS	TREAM	Stream Ord	er:		Stream flow:					
Field Che	emistry	Modifications:	Y/N Can	alised-widene	d-bank e	rosion-	Riffle/Glide			
DO%		arterial drainage					Slow flow			
DO mg/l		Dominant Type Bedrock	es:							
Temp (°C)		Boulder (>128m	m)							
Conductivity		Cobble (32-128n								
pH		Gravel (8-32mm)							
Bank width (cm)	7m	Fine Gravel (2-8)								
Wet width (cm)	6m	Sand (0.25-2mm Silt (<0.25mm)	1)							
Avg Depth (cm)	014	Slope: (ow)- M	odium — l	High - Very F	liah					
Staff gauge					ngri		Shading: High - Modera	te – Low - No	ne	
Velocity	Colour	Geology: Calca							- (-	
(Torrential)	None	Substratum Co	ndition:	: Calcareous-	Compacte	:d-	Cattle access Y: upstream	n – downstrea	am or r	
Fast	Slight	Loose - Normal								
Moderate	Moderate	Substratum: Stoney bottom-	huddy bo	ttom-Mud ove	er etones		Db -4 (2)/ N			
Slow	High			7			Photo: Y/ N			
Very slow Clarity	Discharge	Degree of silta	~							
(Very dear)	Flood	Depth of mud:	None: <	1cm: 1-5cm:	5-10cm:	>10cm			-	
Clear	Normal	Litter: None - P	resent -	Moderate - A	bundant					
Clear	Homai	Filamentous A			_		Sewage Fungus:			
Slightly turbid	Low	None - Present -		ite - Abundan	1		None - Present - Moderat	e - Abundant		
Highly turbid	Very Low	Main land use		_	Sample		Sampled in Minutes:			
	Dry	Pasture		T	retained	l:	Pond net x			
	Recent Flood	Beg		Til lag e Other	Y/N		Stone wash x			
		Forestry		Other			Weed sweep x			
 Group 2 = Pl Group 3 = Ti 	ates are divided into phemeroptera (3-tail lecoptera (2-tails) - r	s) – note that tails note that tails may	ecific gro may be be dama	ups: damaged du	ing samp	bling		Abunda 1-5 6-20 21-50 51-100	1 2 3	
Group 5 = 4	cellus			of each macro	invertebr	ate groui	p below: (Abundance – Ab)	101+	5	
Care in the Law of the Control of	manage deserved	The state of the s		Company of the compan		1,28740		Leuctra Ab	5	
Ephemeroptera:		Ecdyonurus Ab		Plecopte	.a:	-		Isoperla Ab	- 507	
		Rhithrogena Ab		-		-	Punt	onemura Ab	Z	
		Heptagenia Ab	30	- ∤		-				
		Ephemerella Ab					Ampi	<i>ninemura</i> Ab		
	35	Caenis Ab						<i>Perla</i> Ab		
	Par	aleptophlebia Ab		7				<i>Dinocras</i> Ab		
	*	emera danica Ab		7 -		8.	Othe	r Plecop Ab		
	,	Other Ephem Ab		7			Othe	Plecop Ab		
			3	Total no.	of Tava	2	Total Relative	bundance	2	
Total no. of taxa		tive Abundance	100	2004	THE RESERVE OF THE PERSON NAMED IN		Chironomidae (D) Ab 15	The second secon		
Trichoptera:	Hydropsychidae			Lymnaea (-	Chironomus (D) Ab	Abser	nt	
	Polycentropodidae		Pol	tamopyrgus (+	Simuliidae (D) Ab	Few/Low		
9	Rhyacophila		-	Planorbis (1	Dicranota (D) Ab	Common		
	Philopotamidae		_	Ancylus (1	Tipulidae (D) Ab	Numerous		
	Limnephilidae			Physa (C		1	Ceratopogonidae (D) Ab			
j	Sericostomatidae			umbriculus (C		1	Other GOLD Ab	NOTE: As	sellus	
9	Glossosomatidae			Eiseniella (C Tubificidae (C		1	Outer GOLD AD	must be		
ä	Lepidostomatidae		-	Tubilicidae (C	וון אטן	_		recorded a absent if r		
W.A	Other Trichoptera							are found	.5.10	
Total no. of	Total Rela	ative g	1	Total no. of	Гаха 2	_ T	otal Relative Abundance 4	1.		

NOTE Baetis is an Ephemeropteran and is the most commonly occurring invertebrate genus in streams in Ireland. It is vital that Baetis is not counted in SSRS. See Appendix B for more details on how to identify Baetis.

BALLYMORE EUSTACE UPSTREAM

Step 1. Calculate the Index Score by circling the appropriate box representing the total number of taxa and the total abundance calculated from *each macroinvertebrate group* calculated from page 1 of the recording sheet and enter in to the boxes in Step 2.



Step 3. Calculate the Total Index Score, the Average Index Score and the SSR Score using the boxes below

Total Index Score (TIS) Sum (a+b+c+d+e) 20 Average Index Score (AIS) TIS/5 (5 for 5 groups) 4 SSR Score (AIS x 2)

Step 4. Assess the stream by comparing the final SSR score with the categories below and tick the appropriate box

> 7.25
Probably not at risk

Stream may be at risk

> 6.5 – 7.25
Stream at risk

Stream at risk


Surveyor (signed): Karon John Name (print): AAROW SKEHIN Date: 25 / 10 / 22

BALLYMORE EUSTACE DOWNSTREAM

River: Lif		Code:		Date:	25-10			. 36			
Station no.		Location: BALLYMORE EUSTINEE Grid (6 figure):									
		Stream Order: Stream flow:									
Field Ch	nmiets.	Modifications: Y									
DO%		arterial drainage									
DO mg/l		Dominant Types	5:								
Temp (°C)		Bedrock									
Conductivity		Boulder (>128mm Cobble (32-128mr									
рН		Gravel (8-32mm)						15			
Bank width (cm)		Fine Gravel (2-8m									
		Sand (0.25-2mm)									
Wet width (cm)		Silt (<0.25mm)				-					
Avg Depth (cm)	30.	Slope: Low - Med	dium)- H	ligh – Ver	y High	Sh	ading: High - Moder	ate + Low - N	one		
Staff gauge Velocity	Colour	Geology: Calcare	ous-Silic	eous-Mixe	ed			_			
Torrential		Substratum Con	dition:	Calcareou	s-Compacted-	Ca	ttle access Y: upstre	am – downstr	eam or N		
Fast	Slight	Loose - Normal									
Moderate	11000100	Substratum: Stoney bottom-Mu	ما ماداد	ton Mud	avor etanac		6/11				
Slow	11311			_			noto:(Y)/ N				
Very slow Clarity	Disabanes	Degree of siltati									
Very dear	Flood	Depth of mude	Tone <	tcm: 1-5c	m: 5-10cm: >1	L0cm			-		
Clear		Litter: None - Pre	esent - I	Moderate	- Abundant						
		Filamentous Alg	ae:			Se	wage Fungus:				
Slightly turbid		None – Present –		e - Abund	lant		ne - Present - Modera	ete - Abundani			
Highly turbid	Very Low I	Main land use u	/s:		Sample		mpled in Minutes:				
		Pasture		Urban)	retained:	Por	nd net x				
	14000116 1 1000	B o g Forestry		Tillage Other	Y/N	Sto	ne wash x				
		oresay				We	ed sweep x				
 Group 1 = E Group 2 = P 	Mates are divided into the phemeroptera (3-tails) lecoptera (2-tails) - no	 note that tails i 	orate (ups: damaged	during samplin	ng		Relative Abunda 1-5 6-20 21-50			
 Group 3 = Ti Group 4 = G 	ncnoptera .OL.D (Gastropoda, Ol	ligochaeta and Dip	tera)		51-100 4						
• Group 5 = A	sellus						101+ 5				
	total number of taxa	and relative abun	dance of	f each ma	croinvertebrate	e group bek	ow: (Abundance – Ab)		1 12		
Ephemeroptera:		Ecdyonurus Ab		Plecop	tera:			Leuctra Ab	2		
2		Rhithrogena Ab)				Isoperla Ab			
		<i>Heptagenia</i> Ab	8				<i>Protonemura</i> Ab				
	E	Ephemerella Ab		}			Amphinemura Ab				
	-	Caenis Ab		1				<i>Perla</i> Ab			
	Paral	leptophlebia Ab		1				Dinocras Ab			
	·	mera danica Ab		1	-		Ott	ner Plecop Ab			
				ł	· -			er Piecop Ab			
		ther Ephem Ab			o, of Taxa	.]	Total Relative		1		
Total no. of taxa		ve Abundance	2			Chir	ronomidae (D) Ab		dimension of		
Trichoptera:	Hydropsychidae /); 		a(G) Ab I		hironomus (D) Ab	Abs	ent /		
9	Polycentropodidae		Pote	amopyrgu			Simuliidae (D) Ab	Few/Lo			
9	Rhyacophila			Planorbi	The same of the sa		Dicranota (D) Ab	Commor			
a d	Philopotamidae		-		s(G) Ab		Tipulidae (D) Ab	Numerou			
7	Limnephilidae					Carato	ppogonidae (D) Ab				
	Sericostomatidae						Other GOLD Ab	NOTE: A	i <i>sellus</i>		
	Lepidostomatidae		Т	ubificidae				must be recorded	26		
14	Other Trichoptera A		30.1100000	, -, , ,			absent if				
Total no. of Taxa	3 Total Relati	lve a	т	otal no.	of Taxa 3	Total R	elative Abundance	are found			

NOTE Baetis is an Ephemeropteran and is the most commonly occurring invertebrate genus in streams in Ireland. It is vital that Baetis is not counted in SSRS. See Appendix B for more details on how to identify Baetis.

Step 1. Calculate the Index Score by circling the appropriate box representing the total number of taxa and the total abundance calculated from *each macroinvertebrate group* calculated from page 1 of the recording sheet and enter in to the boxes in Step 2.



Step 3. Calculate the Total Index Score, the Average Index Score and the SSR Score using the boxes below

Total Index Score (TIS) sum (a+b+c+d+e) 20 Average Index Score (AIS) TIS/5 (5 for 5 groups) 4 SSR Score (AIS x 2)

Step 4. Assess the stream by comparing the final SSR score with the categories below and tick the appropriate box

> 7.25
Probably not at risk

Stream may be at risk

> 6.5 – 7.25
Stream at risk