

# Annual Environmental Report

2019



Camolin

D0405-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 CAMOLIN SECONDARY DISCHARGE - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - CAMOLIN SECONDARY DISCHARGE
  - 2.1.2 EFFLUENT MONITORING SUMMARY - CAMOLIN SECONDARY DISCHARGE -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CAMOLIN SECONDARY DISCHARGE
  - 2.1.5 SLUDGE/OTHER INPUTS TO CAMOLIN SECONDARY DISCHARGE
- 2.2 CAMOLIN WWTP (NORTH) - TREATED DISCHARGE
  - 2.2.1 INFLUENT SUMMARY - CAMOLIN WWTP (NORTH)
  - 2.2.2 EFFLUENT MONITORING SUMMARY - CAMOLIN WWTP (NORTH) -
  - 2.2.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.2.4 OPERATIONAL REPORTS SUMMARY FOR CAMOLIN WWTP (NORTH)
  - 2.2.5 SLUDGE/OTHER INPUTS TO CAMOLIN WWTP (NORTH)

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

**5 LICENCE SPECIFIC REPORTS**

5.1 PRIORITY SUBSTANCES ASSESSMENT

**6 CERTIFICATION AND SIGN OFF**

6.1 SUMMARY OF AER CONTENTS

**7 APPENDIX**

7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER

This Annual Environmental Report has been prepared for D0405-01, Camolin, in Wexford in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works nor improvements in 2019.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Camolin Secondary Discharge with a Plant Capacity PE of 50, the treatment type is 1 - Primary treatment
- Camolin WWTP (North) with a Plant Capacity PE of 100, the treatment type is 1 - Primary treatment

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF3300D0405SW002	Camolin Secondary Discharge	Treated	Non-Compliant	BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l Suspended Solids mg/l
TPEFF3300D0405SW001	Camolin WWTP (North)	Treated	Non-Compliant	BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l Suspended Solids mg/l

## 1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 CAMOLIN SECONDARY DISCHARGE - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - CAMOLIN SECONDARY DISCHARGE

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
COD-Cr mg/l	6	1320	392.5
Suspended Solids mg/l	7	710	164.5
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	6	976	237.23
Hydraulic Capacity	N/A	263.25	65.82

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is greater than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF3300D0405SW002

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>Suspended Solids mg/l</b>	N/A	N/A	50	8	N/A	N/A	58.01	Fail
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	N/A	N/A	20	6	N/A	N/A	125.5	Fail

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

### Cause of Exceedance(s):

**Inadequate Infrastructure. Discharge failed to achieve Specified Percentage Reduction for Suspended Solids and cBOD in 2019, with 4 breaches of Specified Percent Reduction for Suspended Solids and 3 breaches of Specified Percent age Reduction for cBOD**

### Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF3300D0405SW002

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
<b>Upstream</b>	306226,152641	RS12C080300	No	No	No	No	Unassigned
<b>Downstream</b>	306161,152214	RS12C080330	No	No	No	No	Unassigned

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CAMOLIN SECONDARY DISCHARGE

### 2.1.4.1 Treatment Efficiency Report - Camolin Secondary Discharge

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
<b>COD</b>	9430	6455	32



<b>cBOD</b>	5699	3015	47
<b>SS</b>	3952	1394	65
<b>TP</b>	N/A	N/A	N/A
<b>TN</b>	N/A	N/A	N/A

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - Camolin Secondary Discharge

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

<b>Camolin Secondary Discharge</b>	
<b>Peak Hydraulic Capacity (m<sup>3</sup>/day) - As Constructed</b>	51
<b>DWF to the Treatment Plant (m<sup>3</sup>/day)</b>	9
<b>Current Hydraulic Loading - annual max (m<sup>3</sup>/day)</b>	263.25
<b>Average Hydraulic loading to the Treatment Plant (m<sup>3</sup>/day)</b>	65.82
<b>Organic Capacity (PE) - As Constructed</b>	50
<b>Organic Capacity (PE) - Collected Load (peak week)<sup>Note1</sup></b>	183
<b>Organic Capacity (PE) - Remaining</b>	0
<b>Will the capacity be exceeded in the next three years? (Yes/No)</b>	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - CAMOLIN SECONDARY DISCHARGE

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>There is no Sludge and Other Input data for the Treatment Plant included in the AER.</b>							

## 2.2 CAMOLIN WWTP (NORTH) - TREATED DISCHARGE

### 2.2.1 INFLUENT MONITORING SUMMARY - CAMOLIN WWTP (NORTH)

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	6	711	329.17
<b>COD-Cr mg/l</b>	6	1368	780.33
<b>Suspended Solids mg/l</b>	7	1442	306.03
<b>Hydraulic Capacity</b>	N/A	102	136.01

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

## Significance of Results:

The annual mean hydraulic loading is greater than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

## 2.2.2 EFFLUENT MONITORING SUMMARY - TPEFF3300D0405SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Suspended Solids mg/l	N/A	N/A	N/A	8	N/A	N/A	98.99	Fail
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	N/A	N/A	N/A	6	N/A	N/A	340.83	Fail

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

## Cause of Exceedance(s):

**Inadequate infrastructure. In 2019 discharge failed to comply with Specified Percentage Reduction for cBOD and Suspended Solids on 3 occasions.**

## Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2

## 2.2.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF3300D0405SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
<b>Upstream</b>	307430, 153172	RS12B010500	No	No	No	No	Good
<b>Downstream</b>	306377, 152233	RS12B010600	No	Yes	No	No	Good

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	RS12B010500	2	RS12B010600	2	1.5	0
<b>BOD - 5 days (Total) mg/l</b>	RS12B010500	1	RS12B010600	1.733	1.5	48.9
<b>Ammonia-Total (as N) mg/l</b>	RS12B010300	0.022	RS12B010600	0.049	0.065	42.8
<b>Ammonia-Total (as N) mg/l</b>	RS12B010500	0.053	RS12B010600	0.049	0.065	-5.9
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	RS12B010500	0.029	RS12B010600	0.025	0.035	-11.6

<b>ortho-Phosphate (as P) - unspecified mg/l</b>	RS12B010300	0.013	RS12B010600	0.025	0.035	32.9
<b>BOD - 5 days (Total) mg/l</b>	RS12B010300		RS12B010600	1.733		
<b>Total Oxidised Nitrogen (as N) mg/l</b>	RS12B010300	3.44	RS12B010600	5.3		
<b>pH pH units</b>	RS12B010300	7	RS12B010600	7.239		
<b>pH pH units</b>	RS12B010500	7.139	RS12B010600	7.239		
<b>Temperature °C</b>	RS12B010300	10	RS12B010600	10.26		
<b>Dissolved Oxygen mg/l</b>	RS12B010500	11.306	RS12B010600	11.388		

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.2.4 OPERATIONAL PERFORMANCE SUMMARY - CAMOLIN WWTP (NORTH)

### 2.2.4.1 Treatment Efficiency Report - Camolin WWTP (North)

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
cBOD	16346	16925	-3.54
TN	N/A	N/A	N/A
TP	N/A	N/A	N/A
SS	15197	4916	68
COD	38750	33412	14

Note: The above data is based on sample results for the number of dates reported

#### 2.2.4.2 Treatment Capacity Report Summary - Camolin WWTP (North)

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Camolin WWTP (North)	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	102
DWF to the Treatment Plant (m <sup>3</sup> /day)	17
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	102
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	136.01
Organic Capacity (PE) - As Constructed	100
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	199
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.2.5 SLUDGE / OTHER INPUTS - CAMOLIN WWTP (NORTH)

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>There is no Sludge and Other Input data for the Treatment Plant included in the AER.</b>							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2019.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>Specified % Reduction Value not achieved</b>	WWTP upgrade required to meet ELV	1	Yes	No
<b>Specified % Reduction Value not achieved</b>	WWTP upgrade required to meet ELV	1	Yes	No



### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2019	2
Number of Incidents reported to the EPA via EDEN in 2019	2
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
<b>There are no Storm Water Overflows in this Agglomeration.</b>							

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	N/A
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0405-SIP:01</b>	Construct a new WWTP to comply with ELVs specified in Schedule A	C	31/12/2019	No	Not Started		The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis
<b>D0405-SIP:02</b>	SW002 Secondary Discharge Point to be Discontinued	C	31/12/2019	No	Not Started		The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis

A summary of the status of any improvements identified by under Condition 5.2 is included below.

## 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

## 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2014	No	

### 5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2014

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 30/04/2020

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

## 7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary