

Annual Environmental Report

2020



Clonmel

D0035-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 CLONMEL WWTP - 2020 - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - CLONMEL WWTP - 2020
 - 2.1.2 EFFLUENT MONITORING SUMMARY - CLONMEL WWTP - 2020 -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CLONMEL WWTP - 2020
 - 2.1.5 SLUDGE/OTHER INPUTS TO CLONMEL WWTP - 2020

3 COMPLAINTS SUMMARY

- 3.1 REPORTED INCIDENTS SUMMARY
 - 3.1.1 SUMMARY OF INCIDENTS
 - 3.1.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0035-01, Clonmel, in Tipperary in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no major capital or operational changes undertaken

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- CLONMEL WWTP - 2020 with a Plant Capacity PE of 80000, the treatment type is 3NP - Tertiary N&P removal

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2900D0035SW001	CLONMEL WWTP - 2020	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 CLONMEL WWTP - 2020 - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - CLONMEL WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Phosphorus (as P) mg/l	24	8	2.47
Total Nitrogen mg/l	24	48.5	17.33
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	24	290	135.34
COD-Cr mg/l	24	883	377.44
Suspended Solids mg/l	24	666	200
Hydraulic Capacity	N/A	35170	10925

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2900D0035SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	24	N/A	N/A	15.4	Pass
Suspended Solids mg/l	35	87.5	N/A	24	N/A	N/A	7.28	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	25	50	N/A	24	N/A	N/A	2	Pass
Temperature °C	25	25	N/A	4	N/A	N/A	12.43	Pass
pH pH units	9	9	N/A	24	N/A	N/A	7.9	Pass
Ammonia-Total (as N) mg/l	5	6	N/A	24	N/A	N/A	0.15	Pass
Total Phosphorus (as P) mg/l	2	2.4	N/A	24	N/A	N/A	0.18	Pass
ortho-Phosphate (as P) - unspecified mg/l	1.5	1.8	N/A	24	N/A	N/A	0.1	Pass
Fats, Oils & Greases mg/l	N/A	N/A	N/A	11	N/A	N/A	6.18	
Total Nitrogen mg/l	N/A	N/A	N/A	24	N/A	N/A	9.7	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2900D0035SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	222108, 122715	RS16S022550	No	No	No	No	Good
Downstream	223045, 123054	RS16S022580	No	No	No	No	Good

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS16S022550	2	RS16S022580	2.04	1.5	2.5
Ammonia-Total (as N) mg/l	RS16S022550	0.06	RS16S022580	0.03	0.07	-36.5
ortho-Phosphate (as P) - unspecified mg/l	RS16S022550	0.05	RS16S022580	0.04	0.04	-3.2
Dissolved Oxygen mg/l	RS16S022550	10.49	RS16S022580	10.46		
pH pH units	RS16S022550	8.34	RS16S022580	8.21		
Total Nitrogen mg/l	RS16S022550	2.89	RS16S022580	2.87		
Dissolved Oxygen % O2	RS16S022550	95.05	RS16S022580	95.6		
Temperature °C	RS16S022550	12.54	RS16S022580	12.61		
Total Phosphorus (as P) mg/l	RS16S022550	0.14	RS16S022580	0.13		

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD and Ortho P, concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CLONMEL WWTP - 2020

2.1.4.1 Treatment Efficiency Report - CLONMEL WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
COD	1653902	67491	96
TN	75951	42520	44
cBOD	593036	8777	99
TP	10835	776	93
SS	876385	31911	96

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - CLONMEL WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

CLONMEL WWTP - 2020	
Peak Hydraulic Capacity (m³/day) - As Constructed	24912
DWF to the Treatment Plant (m³/day)	8304

CLONMEL WWTP - 2020	
Current Hydraulic Loading - annual max (m ³ /day)	35170
Average Hydraulic loading to the Treatment Plant (m ³ /day)	10925
Organic Capacity (PE) - As Constructed	80000
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	30354
Organic Capacity (PE) - Remaining	49646
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - CLONMEL WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Landfill Leachate (delivered by tanker)	9214	Volume (m3)	100	100	Yes	Yes	Yes
Industrial / Commercial Sludge	9426	Volume (m3)	110	100	Yes	Yes	Yes

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Industrial / Commercial Sludge	1679	Volume (m3)	20	100	Yes	Yes	Yes
Other	1883	Volume (m3)	25	100	Yes	Yes	Yes
Other	382	Volume (m3)	10	100	Yes	Yes	Yes

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2020.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
There were no reportable incidents in 2020.				

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	1
Number of Incidents reported to the EPA via EDEN in 2020	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SW10	220113, 122226	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
SW11	220039, 122210	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
SW13	219601, 122150	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
SW14	219362, 122118	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SW15	219054, 122086	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
SW16	205052, 124712	Yes	Medium	Meeting	Unknown	Unknown	Monitored

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SW2	220762, 122277	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
SW5	221178, 122381	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
SW6	220544, 122270	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
SW7	220411, 122247	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
SW9	220223, 122253	Yes	Medium	Meeting	Unknown	Unknown	Not Monitored
TBC	220758, 122284	No	Medium	Meeting	Unknown	Unknown	Unknown
TBC	217805, 121359	No	Medium	Meeting	Unknown	Unknown	Unknown
TBC	205054, 124711	No	Medium	Meeting	Unknown	Unknown	Unknown
SW4	221681, 122539	Yes	Low	Unknown	Unknown	Unknown	Not Monitored
SW12	219857, 121823	Yes	Low	Unknown	Unknown	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SW3	221968, 122705	Yes	Low	Unknown	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
There are no Specified Improvement Programmes for this Agglomeration.							

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
There is no Licence Specific Report Required in this AER Annual Review.				

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 24/06/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

Clonmel Ambient Monitoring Data 2020

Category	Entity	Station	Station Reference	Easting	Northing	Sample Refere	Sample Date	Analyst Conclu	Ammonia N	Biological Oxyg	COD Chemical	Dissolved Oxyg	Ortho-Phosph	pH	Temperature	TN	TP
									mg/l	mg/l	mg/l	mg/l	mg/l	pH units	Degrees C	mg/l	mg/l
Ambient Monitoring	River Suir	Upstream @ Clonmel WWTP	RS16S022550	222045	122721	20550080	21/01/2020	-	0.03	2		11.7	0.038	8.6	8.3	1.6	0.14
Ambient Monitoring	River Suir	Downstream @ Clonmel WWTP	RS16S022580	223018	123080	20550079	21/01/2020	-	0.03	2		11.9	0.038	8.5	8.9	1.3	0.11
Ambient Monitoring	River Suir	Upstream @ Clonmel WWTP	RS16S022550	222045	122721	20550258	12/02/2020	-	0.03	2		11.85	0.06	8.4	4.5	3.3	0.11
Ambient Monitoring	River Suir	Downstream @ Clonmel WWTP	RS16S022580	223018	123080	20550257	12/02/2020	-	0.03	2.3		11.86	0.07	8.3	4.4	3	0.11
Ambient Monitoring	River Suir	Upstream @ Clonmel WWTP	RS16S022550	222045	122721	20550355	04/03/2020	-	0.03	2		11.2	0.038	8.6	8.2	3.1	0.12
Ambient Monitoring	River Suir	Downstream @ Clonmel WWTP	RS16S022580	223018	123080	20550340	04/03/2020	-	0.03	2		10.8	0.038	8.6	8.4	2.9	0.08
Ambient Monitoring	River Suir	Upstream @ Clonmel WWTP	RS16S022550	222045	122721	20550541	06/05/2020	-	0.03	2		11.87	0.016	8.6	13.8	3.2	0.05
Ambient Monitoring	River Suir	Downstream @ Clonmel WWTP	RS16S022580	223018	123080	20550542	06/05/2020	-	0.03	2		11.87	0.016	8.58	12.7	3.9	0.04
Ambient Monitoring	River Suir	Upstream @ Clonmel WWTP	RS16S022550	222045	122721	20550764	17/06/2020	-	0.05	2		9.56	0.02	8.13	15.6	nt	nt
Ambient Monitoring	River Suir	Downstream @ Clonmel WWTP	RS16S022580	223018	123080	20550765	17/06/2020	-	0.04	2		9.53	0.015	8.13	15.8	nt	nt
Ambient Monitoring	River Suir	Upstream @ Clonmel WWTP	RS16S022550	222045	122721	20550909	08/07/2020	-	0.22	2		9.53	0.042	8.3	15.9	3	0.18
Ambient Monitoring	River Suir	Downstream @ Clonmel WWTP	RS16S022580	223018	123080	20550910	08/07/2020	-	0.03	2		9.62	0.026	8.2	15.9	3	0.18
Ambient Monitoring	River Suir	Upstream @ Clonmel WWTP	RS16S022550	222045	122721	20551125	26/08/2020	-	0.03	2		7.74	0.13	7.8	15.8	3	0.22
Ambient Monitoring	River Suir	Downstream @ Clonmel WWTP	RS16S022580	223018	123080	20551126	26/08/2020	-	0.04	2		7.66	0.13	7.7	16.3	3	0.22
Ambient Monitoring	River Suir	Upstream @ Clonmel WWTP	RS16S022550	222045	122721	20551208	16/09/2020	-	0.03	2		10.43	0.02	8.3	18.2	3	0.18
Ambient Monitoring	River Suir	Downstream @ Clonmel WWTP	RS16S022580	223018	123080	20551209	16/09/2020	-	0.03	2		10.4	0.022	7.7	18.5	3	0.18
Ambient Monitoring	River Suir	Upstream @ Clonmel WWTP	RS16S022550	222045	122721	20551327	08/10/2020	-	0.05	2		10.14	0.038	8.2	12.3	3	0.18
Ambient Monitoring	River Suir	Downstream @ Clonmel WWTP	RS16S022580	223018	123080	20551328	08/10/2020	-	0.03	2		10.6	0.039	8.2	12.2	3	0.18
Ambient Monitoring	River Suir	Upstream @ Clonmel WWTP	RS16S022550	222045	122721	20551522	11/11/2020	-	0.03	2		10.5	0.032	8.4	12	3	0.18
Ambient Monitoring	River Suir	Downstream @ Clonmel WWTP	RS16S022580	223018	123080	20551521	11/11/2020	-	0.03	2		10.6	0.035	8.4	11.8	3	0.18